

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

AFDD

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

NOARK Electrics (Shanghai) Co., Ltd.
No.3857 Sixian Road, Songjiang District, Shanghai,
P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp: 4kV;Ui: 500V;Ue: AC240V;In: 6A, 10A, 13A, 16A, 20A, 25A, 32A(Type B, Type C);
10A, 13A, 15A, 20A, 25A(Type BK, Type CK);Instantaneous tripping current: Type B, Type C,
Type BK, Type CK;Rated residual tripping current: Type A, Electronic;Ics: 6kA;Icn: 6kA;Poles:
2P;Suitable for isolation

Trademark / Brand (if any)

NOARK

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NB4LE-AFD

Additional information (if necessary may also be reported on page 2)

IEC 62606:2013, AMD1:2017; IEC 62606:2013

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-098909


This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Dec.23,2021

Signature:



Xie ZhaoXu