




## ATTESTATION of conformity with European Directives

*Product:* Residual current protection circuit-breaker  
*Reference* NBTL-2P  
*Issued to* Zhejiang Chint Electric Co., Ltd.  
*Address* No.1 CHINT Road, CHINT Industrial Zone, North Baixiang, Yueqing  
*Manufacturer* Zhejiang Chint Electric Co., Ltd.

*Technical characteristics*



Ue: 240V~(1P+N), 50/60Hz  
Selectivity category: A  
Ie: 15A;30A;45A;60A  
Icu=Ics=6kA  
Ui=415V  
Uimp=6kV  
IP50  
Pollution degree: 3  
Reference temperature: 40°C  
Distance for metal screen:  
Back:0mm Front:0mm; Top:0mm Bottom:0mm; Left:0mm  
Right:0mm(values declared by client)

The submitted sample of the above equipment has been tested for  marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 60947-2:2017+A1:2020 EN 60947-1:2007 + A1:2011 + A2:2014	CNT-ESH-P22100887	05/12/2022

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product  
The  marking may be affixed if all relevant and effective European Directives with  are applicable

Shanghai (P.R. China), December 12<sup>nd</sup>, 2022.

Charlie CHEN  
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.  
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA

必维欧亚电气技术咨询服务(上海)有  
限公司

Building 4, No. 518, Xin Zhuan Road,  
CaoHejing Songjiang High-Tech Park,  
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000  
Fax: +86 21 6195 7001  
Email: [contact@cn.bureauveritas.com](mailto:contact@cn.bureauveritas.com)