

Certificate of Conformity/Approval

Certificate No.: SAA-240447-EA

Certificate Holder: Zhejiang Chint Electrics Co., Ltd

No. 1, Chint Road, Chint Industrial Zone,

North Baixiang, Yueqing, Zhejiang Province, 325603

P.R. China

Regulatory Definition: Miniature Overcurrent Circuit-Breaker

Product Description: Circuit-breakers for overcurrent protection for household

and similar installations (CBOs)

Standard/s: AS/NZS 60898.1:2004

Condition/s: Nil

Comment/s: Suitable for sale in New Zealand subject to compliance

with the Electricity (Safety) Regulations.

Approval Marks: RCM (In accordance with AS/NZS 4417 and EESS requirements)

and

SAA-240447-EA (In accordance with NSW legislative requirements)

Initial Issue Date: 9 April 2024

Expiry Date: 9 April 2029

For and on Behalf of SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein. For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au

JAS-ANZ

www.jas-anz.org/register



Issued: 09-04-24 240447 Page 1 of 2



Certificate of Conformity/Approval

Model Trade Name Rating/Marking

NXB-63 CHINT Un= 220, 230 or 240V~ (1P, 1P+N, 2P) Un= 380, 400 or 415V~ (2P, 3P, 3P+N, 4P)

In= 1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A

50/60Hz, B-, C- & D- type

Ics= Icn= 6000A (1P, 1P+N, 3P, 3P+N, 4P)

Ics= Icn= 6000A (2P, 380, 400 or 415V~)

Ics= 7500A, Icn= 10000A (2P, 220, 230 or 240V~)

For 1P+N and 3P+N, N pole is an unprotected switched neutral pole.

For and on Behalf of SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein. For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register

Issued: 09-04-24 240447 Page 2 of 2