

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Moulded Case Circuit-Breakers (MCCBs)

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.
No.1 Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
Zhejiang Province, P.R. China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

See page 2

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

DZ158-125H, DZ158-125

Additional information (if necessary may also be reported on page 2)

This certificate replaces CB certificate SE-102334M1, dated 26 August 2021. A new certificate has been issued due to a test verification of reference temperature has been added.

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

210600852SHA-001, 210600852SHA-001 A1

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Signature:



Henrik Wikström

Date: 17 June, 2022

Ratings and principal characteristics

$U_e = 230/240V$ for 1P, 400/415V for 2P, 3P, 4P

$I_n = 63, 70, 80, 90, 100, 125A$

DZ158-125H: $I_{cu} = 10kA, I_{cs} = 7,5kA,$

DZ158-125: $I_{cu} = I_{cs} = 6kA$

Cat. A, $I_i = 10I_n, 12I_n, U_{imp} = 4kV, U_i = 500V, 50/60Hz$

ref. temperature: $+30^\circ C, +40^\circ C, +50^\circ C$ and $+55^\circ C$

Date: 17 June, 2022

Signature:

