

Certificate of Conformity

Global-Mark Pty. Ltd., certify the electrical equipment described hereunder complies with standards listed herein and notifies the certificate holder to affix the authorised Approval Mark on the product of the same type and the Regulatory Compliance Mark (RCM) mark provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled. In placing the Approval and RCM mark on the product, the Responsible Supplier makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. – This Certificate meets the requirements of a Recognised External Certification Scheme (EESS- RECS) and a Recognised External Approval Scheme (NSW-REAS).

CERTIFICATION AND CERTIFICATE HOLDER DETAILS

Company Name	Zhejiang Chint Electrics Co.,Ltd.	Other Name	
Address	No.1, Chint Road,Chint Industrial Zone, North Baixiang, Yueqing Zhejiang 325603 China		
Client ID	108754	Global-Mark File Number:	108754-002
Certificate Number & Approval Mark	GMA-516903-EA	Revision Number	00
Certification Standard(s)	AS/NZS IEC 60947.2:2015 Low-voltage switchgear and controlgear Part 2: Circuit-breakers		
Type of Certification	Electrical Safety Product	Scheme	Global-Mark Electrical Product Safety Certification Scheme

System 1 Approval

CERTIFICATE DATES

Certificate Issue Date	24/10/2023
Certificate Last Update Date	
Certification Expiry Date	24/10/2028

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.



Certification Manager





global-mark®

Certificate of Conformity

CERTIFIED ELECTRICAL EQUIPMENT				
Declared Article	Product Description	Trade Name	Model Number	Rating
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker	CHINT	DZ158-125	Ue= 230/240V for 1P, 400/415V for 2P, 3P, 4P In= 63, 70, 80, 90, 100, 125A Cat. A, Ii= 10In, 12In, Uimp= 4kV, Ui= 500V, 50/60Hz Icu= Ics= 6kA
Miniature overcurrent circuitbreaker	Miniature overcurrent circuitbreaker	CHINT	DZ158-125H	Ue= 230/240V for 1P, 400/415V for 2P, 3P, 4P In= 63, 70, 80, 90, 100, 125A Cat. A, Ii= 10In, 12In, Uimp= 4kV, Ui= 500V, 50/60Hz Icu= 10kA, Ics= 7.5kA

RELEVANT TRADEMARK (S)

COMMENTS OR CONDITIONS ON THE CERTIFICATION
Nil

End of document

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.



Certification Manager



JAS-ANZ

