

Test Report

Name of products: NTH1 Cumb Bus-bar

Type: NTH1-250/48



Applicant: Zhejiang CHINT Electrics Co., Ltd.

Kind of test: Commission test

DEKRA Testing Services (Zhejiang) Co., Ltd



Test Report

Project No.	3324768	Trade mark	/		
Name of Product	NTH1 Comb Bus-bar	Type	NTH1-250/48		
Rated parameters	2#: Ue = 415 Vac, In = 250 A, Icw = 17kA/0.25s		Pole number	/	
Applicant	Name	Zhejiang CHINT Electrics Co., Ltd.			
	Address	No. 1 CHINT Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R. China			
Manufacturer	Name	/			
	Address	/			
Quantity of samples	1 PC	Contact Person	Zelong Lu	Date of sample available	2022-04-05
Test requirements	Commission Testing agreement : 3324768				
Test duration	2022-05-09				
Test result	Pass		Issue date	2022-05-16	
Subcontract	Subcontractor Laboratory	Qualification No.	Within the scope: <input type="checkbox"/>		
	NEQS	CMA: 190008223452	Beyond the scope: <input checked="" type="checkbox"/>		
Remarks					
Tested by	<i>Tomas</i>	Reviewed by		Approved by	<i>Tomas</i>