



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE190305006628

Product Comprehensive Protector For Motor

Applicant Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model JD-5,JD-5A,JD-5E,JD-5E/T,JD-8;

Technical data See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
03601-A-19D0089-S-A;03601-A-19D0089-S-B, the submitted sample(s) of the above
item complies with:

EN60947-5-1:2017

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Dec.16,2019

Valid until: Dec.16,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE190305006628

JD-5,JD-5A,JD-5E,JD-5E/T,JD-8;
Ui:690V; Uimp:4kV;Ue: AC220V,AC380V;
Ie :JD-5:0.5A ~ 5A,2A ~ 20A,1A ~ 80A,20A ~ 80A,80A ~ 200A,160A ~ 400A;
JD-5A:1A ~ 5A,5A ~ 20A,20A ~ 80A,80A ~ 200A,160A ~ 400A;
JD-5E:1A ~ 5A,5A ~ 25A,20A ~ 80A;
JD-5E/T:1A ~ 5A,5A ~ 25A,20A ~ 80A;
JD-8: 0.5A ~ 5A,2A ~ 20A,20A ~ 80A,32A ~ 80A,64A ~ 160A;
Trip class: JD-5,JD-5E,JD-5E/T:10A;JD-5A:10,JD-8:30;
Number of poles:3P;
Attached auxiliary contact (1NO,1NC,1NONC):
Ui:380V; Uimp:2.5kV;lth:5A;
AC-15:Ue /Ie:AC380V/0.95A,AC220V/1.5A;

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>