



Ref. Certif. No.

CN13938-M3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Air Circuit-breakers
Name and address of the applicant	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the manufacturer	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the factory	Zhejiang CHINT Electrics Co., Ltd. No.1318, Binhai No.2 Avenue, Economic and Technical Development Zone, Wenzhou City, Zhejiang Province, P.R.China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	See the Appendix
Trademark (if any)	CHINT
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	NA1-1000X
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2006(4th Edition) + AMD 1:2009 + AMD 2:2013
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2017CQC-076192-A1/M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>



Date: Dec.23,2019

Signature:

Lu Mei

CB 0055331

NA1-1000X
Uimp:12kV;
Ui:1000V
Ue: AC400V, AC690V
In: 200A,400A,630A,800A,1000A
Over-current release: Electronic;
Ics: Ics=30kA(AC400V), 20kA(AC690V)
Icu: Icu=42kA(AC400V), 25kA(AC690V)
Icw: Icw=30kA/1s(AC400V), 20kA/1s(AC690V)
Selectivity category: B;
3P, 4P
Applicable for insulation;
50/60Hz
Auxiliary contact:
4NO4NC, 6NO6NC
Ui: 400V
Ith: 6A
AC-15: Ue/Ie: AC400V/0.25A,AC230V/1.3A
DC-13: Ue/Ie: DC220V/0.27A,DC110V/0.55A

Page 1 of 1

Additional information (if necessary)

Date: Dec.23,2019

Signature: 

Lu Mei