

IEC

IECEE



Ref. Certif. No.

CN55338-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Air Circuit Breaker

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang  
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang  
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

Wenzhou CHINT Electrics Technology Co., Ltd.  
No.1318, Binhai No.2 Avenue, Economic and Technical  
Development Zone, Wenzhou City, Zhejiang Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NA1-2000X, NA1-2000XN, NA1-2000XH;

Additional information (if necessary may also be  
reported on page 2)Original CB certificate No. is CN55338, dated 2021-11-23. The  
issuance of the M1 certificate is to change parameters.A sample of the product was tested and found  
to be in conformity withIEC 60947-2:2016/AMD1:2019; IEC 60947-2:2016(5th  
Edition); IEC 60947-1:2007; IEC  
60947-1:2007/AMD1:2010; IEC 60947-1:2007/AMD2:2014As shown in the Test Report Ref. No. which  
forms part of this Certificate

00901-CB2021CQC-097461-M1

This CB Test Certificate is issued by the National Certification Body

## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jan.30,2024

Signature:

谢肇煦

Xie ZhaoXu



NA1-2000X, NA1-2000XN, NA1-2000XH

Uimp: 12kV;

Ui: 1000V;

Ue: AC400V, AC415V, AC480/500V, AC690V;

In: 630A, 800A, 1000A, 1250A, 1600A, 2000A;

Over-current release: Electronic;

NA1-2000X:

AC400V :Icu=80kA, Ics=65kA, Icw=50kA /1s, Icw=42kA /3s;

AC415V :Icu=50kA, Ics=50kA, Icw=50kA /1s, Icw=42kA /3s;

AC480/500V:Icu=50kA, Ics=50kA, Icw=50kA /1s;

AC690V :Icu=50kA, Ics=50kA, Icw=50kA /1s;

NA1-2000XN:

AC400V :Icu=50kA, Ics=50kA, Icw=50kA /1s, Icw=42kA /3s;

AC415V :Icu=40kA, Ics=40kA, Icw=40kA /1s, Icw=42kA /3s;

AC690V :Icu=40kA, Ics=40kA, Icw=40kA /1s;

NA1-2000XH:

AC400V :Icu=65kA, Ics=65kA, Icw=50kA /1s, Icw=42kA /3s;

AC415V :Icu=50kA, Ics=40kA, Icw=40kA /1s, Icw=42kA /3s;

AC690V :Icu=50kA, Ics=40kA, Icw=40kA /1s;

Selectivity category:B;

3P,4P;

Suitability for isolation;

Rated frequency:50/60Hz;

Auxiliary contact:

4NO4NC,6NO6NC;

Ui: 415V;

Ith: 6A;

Ue/Ie: AC-15: AC400V/0.75A, AC230V/1.3A;

DC-13: DC220V/0.27A, DC110V/0.55A

Page 1 of 1

Additional information (if necessary)

Date:

Jan.30,2024

Signature:

谢肇煦  
Xie ZhaoXu