



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE220304007907

Product

Switch-disconnectors

Applicant

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model

NH1-3200;

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
00901-CE2022CQC0304-013001, the submitted sample(s) of the above item complies
with:

EN IEC 60947-3:2021

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only,
and does not include the manufacturing process. Users shall affix the mark in accordance
with the related legislation.

Valid from: Nov.07,2022

Valid until: Nov.06,2025

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R. China

Tel: +86 10 83886666

CE 0013251



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE220304007907

NH1-3200

Uimp:8kV;Ui:1000V;lth:3200A;

Ue:AC400V,AC690V;

Ie:2000A,2500A,2900A,3200A;

Icw:80kA/1s;

Icm(peak):176kA;

Utilization category:AC-21A;

Number of poles:3P,4P;50Hz;

IP20(only form front side);

Auxiliary contact:AX-12;

4NO4NC,6NO6NC;

Ith:6A;

DC-13:Ue/Ie:DC110V/0.55A,DC220V/0.27A;

AC-15:Ue/Ie:AC230V/1.3A,AC400V/0.75A.



CHINA QUALITY CERTIFICATION CENTRE

