



Ref. Certif. No.

SE-108293M3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Circuit-breakers for overcurrent protection for household and similar installations (CBOs)
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.China
Name and address of the manufacturer	Same as applicant
Name and address of the factory	Same as applicant
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See page 2
Trademark / Brand (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	NB1-63, NB1-63H
Additional information (if necessary may also be reported on page 2)	<input checked="" type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60898-1:2015+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	230100201SHA-001 230100201SHA-001M1


This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 16 November, 2023



Signature:



Fredrik Wennersten



Ref. Certif. No.

SE-108293M3

Ratings and principal characteristics

U_e= 110 or 230/400 or 240/415V~(1P), 230 or 240V~(1P+N), 110 or 400 or 415V~(2P), 400 or 415V~ (3P, 3P+N, 4P)

I_n= 1, 1,6, 2, 3, 4, 5, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63A(30°C)

I_n= 1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A(55°C)

I_{cs}= 7500A, I_{cn}=10000A (for NB1-63H)

I_{cs}= I_{cn}= 6000A (for NB1-63)

B-, C- & D- type, 50/60Hz, Energy limiting class 3.

Additional information

This certificate replaces previously issued certificate ref. No. SE-108293M2 dated 13 January 2023 for the same model. A new certificate has been issued on account of adding "110V~" to 1P and 2P.

Date: 16 November, 2023

Signature: