



Ref. Certif. No.

**SE-112939**

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product	Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.China
Name and address of the manufacturer	Same as applicant
Name and address of the factory	Same as applicant
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See page 2
Trademark / Brand (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	NB1L
Additional information (if necessary may also be reported on page 2)	<input checked="" type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61009-1:2010+A1+A2 IEC 61009-2-2:1991
As shown in the Test Report Ref. No. which forms part of this Certificate	2311A0746SHA-001

This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden  
Date: 02 January, 2024

**intertek**

Signature:

Fredrik Wennersten

**Ratings and principal characteristics**

Un= 220, 230, 240V~ (2P), 50/60Hz  
In= 6, 10, 13, 16, 20, 25, 32, 40A; B- & C- type  
I $\Delta$ n= 30, 100, 300mA; type -A & -AC  
Icn= 10000A, Ics= 7500A  
Ui= 500V, Uimp= 4kV, Energy limiting class 3.

**Additional information**

The products have also been checked according to:  
AS/NZS 61009.1:2015  
EN 61009-1:2012+A1:2014+A2:2014+A11:2015+A12:2016+A13:2021  
BS EN 61009-1:2012+A13:2021

Date: 02 January, 2024

Signature: 