


CERTIFICATE
FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2400003

**Residual current operated circuit-breakers
with integral overcurrent protection for
household and similar uses (RCBOs)**

Type designation: NB1L

Certificate holder: Zhejiang Chint Electric Co., Ltd.
No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang
Province, P.R.China

**The product complies with
the standard(s):** EN 61009-1:2012+A1+A2+A11+A12+A13


Date of expiry: 02 January, 2029

EU Directive information: According to the principle of presumption of conformity, this certificate
constitutes support for an EU Declaration of Conformity to the Low
Voltage Directive 2014/35/EU.

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:



Date: 02 January, 2024

Fredrik Wennersten

APPENDIX:

Reference No. SE-S-2400003

Technical Data:

Type designation NB1L
Rated voltage (V) 220, 230, 240V~
Rated current (A) 6, 10, 13, 16, 20, 25, 32, 40A
Frequency (Hz) 50/60Hz
IP-Class IP20
Poles No. 2P
Trademark **CHNT**
Test Report 2311A0746SHA-001
Product information B- & C- type, type -A & -AC
I Δ n= 30, 100, 300mA
Icn= 10000A, Ics= 7500A
Ui= 500V, Uimp= 4kV, Energy limiting class 3.


Manufacturing Sites:

Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang
Province, P.R.China

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EC Declaration of Conformity according to the Low Voltage Directive 2014/35/EU. This presumption can expire before the end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:



Date: 02 January, 2024

Fredrik Wennersten