

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

|                                                                           |                                                                                                                                                                                                                                                                                                                                 |
|---------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Product                                                                   | Residual current operated circuit-breakers with integral overcurrent protection (RCBOs)                                                                                                                                                                                                                                         |
| Name and address of the applicant                                         | Zhejiang Chint Electrics Co., Ltd.<br>No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang<br>China                                                                                                                                                                                               |
| Name and address of the manufacturer                                      | Zhejiang Chint Electrics Co., Ltd.<br>No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang<br>China                                                                                                                                                                                               |
| Name and address of the factory                                           | <input type="checkbox"/> Additional information on page 2<br>Zhejiang Chint Electrics Co., Ltd.<br>No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang<br>China                                                                                                                                  |
| Note: When more than one factory, please report on page 2                 |                                                                                                                                                                                                                                                                                                                                 |
| Ratings and principal characteristics                                     | 1P+N, Ue: 230 Vac, 50 / 60 Hz<br>In: 6, 10, 16, 20, 25, 32, 40 A, B and C type<br>I $\Delta$ n: 30 mA, type A and AC, without time-delay<br>Ics = Icn = 6 kA of NB2LE, Ics = Icn = 4,5 kA of NB2LE-N,<br>I $\Delta$ m: 3000 A, the grid distance "a": 45 mm.<br>The neutral pole is interrupted without overcurrent protection. |
| Trademark (if any)                                                        | CHINT                                                                                                                                                                                                                                                                                                                           |
| Customer's Testing Facility (CTF) Stage used                              |                                                                                                                                                                                                                                                                                                                                 |
| Model / Type Ref.                                                         | NB2LE, NB2LE-N                                                                                                                                                                                                                                                                                                                  |
| Additional information (if necessary may also be reported on page 2)      | <input type="checkbox"/> Additional information on page 2                                                                                                                                                                                                                                                                       |
| A sample of the product was tested and found to be in conformity with     | IEC 61009-1:2010, IEC 61009-1:2010/AMD1:2012, IEC 61009-1:2010/AMD2:2013, IEC 61009-2-2:1991<br><br>National differences:<br>AU<br>3323694.50                                                                                                                                                                                   |
| As shown in the Test Report Ref. No. which forms part of this Certificate |                                                                                                                                                                                                                                                                                                                                 |

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands