



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE200314007062

Product Miniature Circuit-breakers

Applicant Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model NB8-40J

Technical data Uimp:4kV; Ui:500V; Ue:AC230V/400V(1P), AC400V(2P,3P,4P);
In:1A,2A,3A,4A,6A,10A,16A,20A,25A,32A,40A; Type of instantaneous tripping current:Type B, Type C, Type D;
Ics=Icn:6000A(type B, type C); Ics=Icn:4500A(type D); 1P,2P,3P,4P

This is to certify that, on the basis of the tests undertaken as per Report No. 03601-A-20D0097-S, the submitted sample(s) of the above item complies with:

EN 60898-1:2003 + A11:2005

and fulfills testing requirements of the European Directive:

Low Voltage Directive (LVD): 2014/35/EU

Valid from: Dec.22,2020

Valid until: Dec.22,2023

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

CE 0010609