

Zertifikat

Certificate



Zertifikat Nr. Certificate No. R 50546656	Blatt Sheet 0001	
Ihr Zeichen Client Reference W.Z.W.	Unser Zeichen Our Reference 01-WTH-CN22SN03 001	Ausstellungsdatum Date of Issue 02.06.2022 (day/mo/yr)

Genehmigungsinhaber License Holder Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road,Chint Industrial Zone, North Baixiang Yueqing 325603 Zhejiang P.R. China	Fertigungsstätte Manufacturing Plant Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road,Chint Industrial Zone, North Baixiang Yueqing 325603 Zhejiang P.R. China
---	---

Prüfzeichen Test Mark **Geprüft nach Tested acc. to**
EN 60898-1:2019



Zertifiziertes Produkt (Geräteidentifikation) Certified Product (Product Identification) **Lizenzentgelte - Einheit License Fee - Unit**

Circuit Breaker (Miniature Circuit Breaker)

Type Designation	: NB8-63 (Chint)	5
Ratings of AC:		
Number of Poles	: 1) 1P/1P+N; 2) 2P/3P/3P+N/4P	
Nature of Supply	: AC 50/60Hz	
Rated Operation Voltage (Ue)	: 1) 230/400VAC (1P), 230VAC (1P+N); 2) 400VAC	
Rated Current (In)	: 1/2/3/4/6/10/16/20/25/32/40/ 50/63A	
Instantaneous Tripping Current:	B/C/D-Type	
Rated Short-circuit Breaking Capacity (Icn)	: 6kA	
Rated Service Short-circuit Breaking Capacity (Ics)	: 6kA	
Rated Insulation Voltage (Ui)	: 500V	
Rated Impulse Voltage	: 4kV	
Suitability for Isolation	: Yes	
Pollution degree	: 2	

5

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.



Zertifizierungsstelle

Wencai Zhang

Wencai Zhang

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935