



Ref. Certif. No.
SE-93948

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Circuit-breakers for overcurrent protection for household and similar installations (CBOs)
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R. China
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	See page 2
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	NBH8-40H, NBH8-40
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 60898-1:2015
As shown in the Test Report Ref. No. which forms part of this Certificate	181002298SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 26 April 2019

intertek

Signature:

Henrik Wikström

Factories

$U_n = 230/240V \sim (1P+N)$

$I_n = 1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40A$

B-, C- type, 50/60Hz

$I_{cn} = I_{cs} = 6000A$ (NBH8-40H), $I_{cn} = I_{cs} = 4500A$ (NBH8-40)

Energy limiting class 3

Date: 26 April 2019

Signature:

