



# CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE210303007497

**Product** Moulded Case Circuit Breaker

**Applicant** Zhejiang CHINT Electric Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang  
Town, Yueqing City, Zhejiang Province, P.R.China

**Type/Model** NBP-63R

**Technical data** Uimp: 6kV;Ui: 690V;Ue: AC230V(1P), AC400V(2P, 3P,  
4P);In: 1A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A,  
32A, 40A, 50A, 63A;Over-current release type:  
Thermal-magnetic;Ics: 7.5kA;Icu: 15kA;Selectivity  
category: A;Poles: 1P, 2P, 3P, 4P;Suitable for isolation;Rated  
frequency: 50/60Hz;

This is to certify that, on the basis of the tests undertaken as per Report No.  
00901-CB2021CQC-100192, the submitted sample(s) of the above item complies with:

**EN 60947-2:2017**

and fulfills testing requirements of the European Directive:

**2014/35/EU**

This report is to verify the compliance of the sample submitted by the manufacturer only,  
and does not include the manufacturing process. Users shall affix the mark in accordance  
with the related legislation.

**Valid from:** Dec.13,2021

**Valid until:** Dec.13,2024

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE

