

**IEC****IECEE**

®

TM

Ref. Certif. No.

CN54772

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

AC CONTACTOR

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town,  
Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town,  
Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Zhejiang CHINT Electrics Co., Ltd.  
No.2 Changjiang Road, CHINT Intelligent Electric Appliance  
Industrial Zone, North Baixiang, Yueqing, Wenzhou, Zhejiang  
Province, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NC7-40\*\*,NC7-50\*\*,NC7-65\*\*,NC7-40\*\*N,  
NC7-50\*\*N,NC7-65\*\*N;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-098427

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

谢肇煦

Signature:

Xie ZhaoXu

Date: Sep.18,2021

**CB 0063834**



NC7-40\*\*,NC7-50\*\*,NC7-65\*\*,NC7-40\*\*N, NC7-50\*\*N,NC7-65\*\*N(\*\*=Type and number of contacts)

Ui:690V;

Uimp:8kV;

Ith: 60A(NC7-40\*\*,NC7-40\*\*N),80A(NC7-50\*\*, NC7-50\*\*N, NC7-65\*\*, NC7-65\*\*N);

Ue: AC220V/230V, AC380V/400V, AC660V/690V;

NC7-40\*\*,NC7-40\*\*N:

AC-1:Ue/Ie:AC220V/230V/60A,AC380V/400V/60A,AC660V/690V/60A;

AC-3:Ue/Ie:AC220V/230V/40A,AC380V/400V/40A,AC660V/690V/34A;

AC-4:Ue/Ie:AC220V/230V/18.5A,AC380V/400V/18.5A,AC660V/690V/9A;

NC7-50\*\*,NC7-50\*\*N:

AC-1:Ue/Ie:AC220V/230V/80A,AC380V/400V/80A,AC660V/690V/80A;

AC-3:Ue/Ie:AC220V/230V/50A,AC380V/400V/50A, AC660V/690V/39A;

AC-4:Ue/Ie:AC220V/230V/24A,AC380V/400V/24A, AC660V/690V/12A;

NC7-65\*\*,NC7-65\*\*N:

AC-1:Ue/Ie:AC220V/230V/80A,AC380V/400V/80A,AC660V/690V/80A;

AC-3:Ue/Ie:AC220V/230V/65A,AC380V/400V/65A,AC660V/690V/42A;

AC-4:Ue/Ie:AC220V/230V/28A,AC380V/400V/28A,AC660V/690V/14A;

Us: AC24V,AC36V,AC42V,AC48V,AC110V,AC120V,AC127V,AC200V,AC208V,AC220V, AC230V,AC240V,AC277V,AC380V,AC400V,AC415V,AC440V,AC460V,AC480V,AC500V, AC525V,AC600V,AC660V, 50Hz,60Hz,50/60Hz;

IP10;

3P;

Auxiliary contact:

1NO1NC(body contact),1NO1NC,2NO,2NC,4NO,4NC,2NO2NC,1NO3NC,3NO1NC (AX-3);

Ith: 10A;

AC-15:Ue/Ie: AC380/400V/0.95A;

DC-13:Ue/Ie: DC220/250V/0.15A.

Page 1 of 1

Additional information (if necessary)

Date:

Sep.18,2021

Signature:

谢肇煦

Xie ZhaoXu