



# CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE210305007463

**Product**

AC Contactor

**Applicant**

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang  
Town, Yueqing City, Zhejiang Province, P.R.China

**Type/Model**

NC8-1260,NC8-1260/W;

**Technical data**

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.  
00901-CE2021CQC0305-012409, the submitted sample(s) of the above item complies  
with:

**EN IEC 60947-4-1:2019**

and fulfills testing requirements of the European Directive:

**2014/35/EU**

This report is to verify the compliance of the sample submitted by the manufacturer only,  
and does not include the manufacturing process. Users shall affix the mark in accordance  
with the related legislation.

**Valid from:** Nov.18,2021

**Valid until:** Aug.17,2024

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE





# CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE210305007463

NC8-1260,NC8-1260/W

Ui:1140V;

Uimp:8kV;

Ith:1260A;

AC-1:Ue/Ie: AC230V/400V/690V/1000V/1140V/1260A;

Us:

NC8-1260:48V,110V,127V,220V,230V,240V,380V,400V,415V,50/60Hz/DC;

NC8-1260/W:100~250V,250~500V,50/60Hz/DC;

3P;

Auxiliary contacts:

NCF1-11C

2NO2NC;

Ith:10A;

AC-15: Ue/Ie:AC24V/6A, AC230V/3.13A, AC400V/1.8A,AC690V/1.04A;

DC-13: Ue/Ie:DC125V/0.55A,DC250V/0.27A



CHINA QUALITY CERTIFICATION CENTRE

