

CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Certificate No.: CE240305008813

Product AC Contactor

Applicant Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model NC8-25□□/□□/□, NC8-32□□/□□/□, NC8-38□□/□□/□, NC8-25
□□/□□/□/□, NC8-32□□/□□/□/□, NC8-38□□/□□/□/□

Technical data See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2024CQC0305-014627, the submitted sample(s) of the above item complies with:

EN IEC 60947-4-1:2019

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Apr.17,2024

Valid until: Apr.16,2027

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 2

Certificate No.: CE240305008813

NC8-2500/00/0,NC8-3200/00/0,NC8-3800/00/0,NC8-2500/00/0/N,
NC8-3200/00/0/N,NC8-3800/00/0/N

Uimp:6kV;

Ui:690V;

Ue:AC240(230/220)V,AC415(400/380)V,AC690(660)V;

NC8-2500/00/0,NC8-2500/00/0/N:

Ith:40A;

AC-1:AC240(230/220)V/40A,AC415(400/380)V/40A ,AC690(660)V/40A;

AC-3:AC240(230/220)V/25A,AC415(400/380)V/25A,AC690(660)V/17.3A;

AC-4:AC240(230/220)V/25A,AC415(400/380)V/25A,AC690(660)V/14A;

NC8-3200/00/0,NC8-3200/00/0/N:

Ith:50A;

AC-1:AC240(230/220)V/50A,AC415(400/380) V/50A,AC690(660)V/50A;

AC-3:AC240(230/220)V/32A,AC415(400/380)V/32A,AC690(660)V/21.9A;

AC-4:AC240(230/220)V/32A,AC415(400/380)V/32A,AC690(660)V/17.3A;

NC8-3800/00/0,NC8-3800/00/0/N:

Ith:50A;

AC-1:AC240(230/220)V/50A,AC415(400/380) V/50A ,AC690(660)V/50A;

AC-3:AC240(230/220)V/38A,AC415(400/380)V/38A,AC690(660)V/21.9A;

AC-4:AC240(230/220)V/38A,AC415(400/380)V/32A,AC690(660)V/17.3A;

Us:AC24V,36V,42V,48V,110V,120V,127V,200V,220V,230V,240V,277V,380V,400V,415V,

440V,460V,480V,600V,660V(50Hz);

AC24V,36V,42V,48V,110V,120V,127V,200V,220V,230V,240V,277V,380V,400V,415V,440V,460V,

480V,600V,660V(50/60Hz);

DC24V,48V,110V,125V,220V;

AC/DC24V~60V,48V~130V,100V~250V,50/60Hz;

3P,4P(4NO,2NO+2NC);



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 2

Certificate No.: CE240305008813

IP20(Front Side);


Auxiliary contact :(Body)

2NO2NC,1NO1NC,2NO,2NC,2NO1NC,1NO2NC,1NO,1NC;

Ith:10A;

AC-15:Ue/Ie:AC380V/400V/415V/1.5A;

DC-13:Ue/Ie:DC220V/250V/0.3A



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE