

C E R T I F I C A T E



of Conformity
Low Voltage Directive 2014/35/EU

Registration No.: AN 50488292 0002

Report No.: 15079067 002

Holder: Zhejiang Chint Electrics Co., Ltd.
No.1,
Chint Road,Chint Industrial Zone,
North Baixiang
Yueqing
325603 Zhejiang
P.R. China

Product: Magnetic Contactor
(AC Contactor)

Identification: Type Designation : NCK3-75
Standard : EN IEC 60947-4-1:2019
Ratings : AC-8a; Ue=230(220)/400(380)VAC; Ie=75A
Ue=600VAC, Ie=50A; Ith=100A; Ui=690V; Uimp=6,0kA; 3P,
Us= AC24V/36V/110V/120V/220V/240V/277V/480V, 50/60Hz
Serial No. : Engineering samples
Remark: Refer to test report 15079067 002 for details.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Date 29.12.2020

Certification Body
A circular blue stamp with the text 'TÜV Rheinland LGA Products GmbH' around the top edge and 'Zertifizierungsstelle III' around the bottom edge. In the center is the TÜV Rheinland logo. A signature in blue ink is written across the stamp.
Kenny Shi

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may be used if all relevant and effective EC Directives are complied with. CE

C E R T I F I C A T E



of Conformity Low Voltage Directive 2014/35/EU

Registration No.: AN 50488292 0001

Report No.: 15079067 002

Holder: Zhejiang Chint Electrics Co., Ltd.
No.1,
Chint Road, Chint Industrial Zone,
North Baixiang
Yueqing
325603 Zhejiang
P.R. China

Product: Magnetic Contactor
(AC Contactor)

Identification:
Type Designation : NCK3-90
Standard : EN IEC 60947-4-1:2019
Ratings : AC-8a, Ue=230(220)/400(380)VAC, Ie=90A
Ue=600VAC, Ie=60A, Ith=100A, Ui=690V, Uimp=6,0kA, 3P,
Us= AC24V/36V/110V/120V/220V/240V/277V/480V, 50/60Hz
Serial No. : Engineering samples
Remark: Refer to test report 15079067 002 for details

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Date 29.12.2020

Certification Body
The seal of TÜV Rheinland LGA Products GmbH, featuring a blue triangle with a white 'A' shape inside, surrounded by the text 'TÜV Rheinland LGA Products GmbH' and 'Zertifizierungsstelle III'.
Kenny Shi

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may be used if all relevant and effective EC Directives are complied with. **CE**