



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE210305007447-A1

Product

Dust proof AC contactor

Applicant

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model

NCX1-9,NCX1-12,NCX1-18,NCX1-9/22,NCX1-12/22,NCX1-18/22,NCX1-9/22N,NCX1-12/22N,NCX1-18/22N;

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. (2021)FQIIDQCE-0234-A1, the submitted sample(s) of the above item complies with:

EN IEC 60947-4-1:2019

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Mar.16,2023

Valid until: Nov.08,2024

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE





CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE210305007447-A1

NCX1-9,NCX1-12,NCX1-18,NCX1-9/22,NCX1-12/22,NCX1-18/22,NCX1-9/22N,
NCX1-12/22N,NCX1-18/22N;
Uimp:8kV;Ui:690V;lth:25A;
NCX1-9,NCX1-9/22,NCX1-9/22N:
Ue/Ie:AC220V/9A,AC380V/9A,AC660V/6.6A;
NCX1-12,NCX1-12/22,NCX1-12/22N:Ue/Ie: AC220V/12A,AC380V/12A,AC660V/8.9A;
NCX1-18,NCX1-18/22,NCX1-18/22N:
Ue/Ie:AC220V/18A,AC380V/18A,AC660V/12A;
Utilization category: NCX1-9,NCX1-12,
NCX1-18,NCX1-9/22,NCX1-12/22,
NCX1-18/22:AC-3;
NCX1-9/22N,NCX1-12/22N,NCX1-18/22N:
AC-4;Us:AC380V,AC220V,AC127V,AC110V,
AC36V,AC24V,50Hz;
3P;IP50(Except for the terminal);
Auxiliary contact:
NCX1-9,NCX1-12,NCX1-18: 1NO1NC;
NCX1-9/22,NCX1-12/22,NCX1-18/22: 2NO2NC;
Uimp:6kV;Ui:690V;lth=10A;
AC-15:Ue:AC380V/220V,Ie:0.95A;
DC-13: Ue:220V/110V,Ie:0.15A



CHINA QUALITY CERTIFICATION CENTRE

