



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE210305007437

Product Dust proof AC contactor

Applicant Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model NCX1-22,NCX1-25,NCX1-32,NCX1-38;

Technical data See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. (2021)FQIIDQCE-0235, the submitted sample(s) of the above item complies with:

EN IEC 60947-4-1:2019

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Nov.08,2021

Valid until: Nov.08,2024

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R. China

Tel: +86 10 83886666

CE 0012629



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE210305007437

NCX1-22,NCX1-25,NCX1-32,NCX1-38

Uimp:8kV;Ui:690V;lth:50A;

NCX1-22:Ue/le:AC220V/22A,AC380V/22A,AC660V/14A;

NCX1-25:Ue/le:AC220V/25A,AC380V/25A,AC660V/18A;

NCX1-32:Ue/le:AC220V/32A,AC380V/32A,AC660V/22A;

NCX1-38:Ue/le:AC220V/38A,AC380V/38A,AC660V/22A;

AC-3;Us:AC380V,AC220V,AC127V,AC110V,AC36V,AC24V,50Hz;

3P,IP50(Except for the terminal);

Auxiliary contact:1NO1NC;Uimp:6kV,Ui:690V,lth:10A;

AC-15:Ue:AC380V/220V,le:0.95A;

DC-13:Ue:AC220V/110V,le:0.15A.



CHINA QUALITY CERTIFICATION CENTRE

