

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50504634

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
C.C.H.

Unser Zeichen *Our Reference*
01-WTH-CN213IDH 002

Ausstellungsdatum *Date of Issue*
17.05.2021
(day/mo/yr)

Genehmigungsinhaber *License Holder*
Zhejiang Chint Electrics Co., Ltd.
No.1,
Chint Road, Chint Industrial Zone,
North Baixiang
Yueqing
325603 Zhejiang
P.R. China

Fertigungsstätte *Manufacturing Plant*
040-0002117948

Prüfzeichen *Test Mark*

Geprüft nach *Tested acc. to*
EN 60947-3:2009+A1+A2



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111240122

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Switch-disconnector (Switch-disconnector)

Type Designation: NF2-wxy-z
(w=DI, H or DO); (x=40, 80 or 125)
(y=blank or R); (z=3 or 4)

8

Utilization Category : AC-23A
Number of Pole : 3P/4P (z=3/4)
Rated Operational Voltage (Ue) : 380/400/415V
Rated Frequency : AC 50/60Hz
Conventional Free Air Thermal
Current (Ith) : 40/80/125A (x=40/80/125)
Rated Current (Ie) : 16A, 25A, 32A, 40A (x=40)
50A, 63A, 80A (x=80)
100A, 125A (x=125)
Rated Insulation Voltage (Ui) : 800V
Impulse Withstand Voltage (Uimp) : 8,0kV
Short-time Withstand Current (Icw) : 2,75kA, 1s
Short-circuit Making Capacity (Icm) : 3,9kA
Pollution Degree : 3
Degree of Protection : IP20
Suitability for Isolation : Yes

8

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com

Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



Hao Zheng

Zhejiang Chint Electrics Co., Ltd.
Chen chuihe

Date : 17.05.2021
Our ref. : WTH 01
Your ref.: C.C.H.

No.1,
Chint Road, Chint Industrial Zone,
North Baixiang
Yueqing
325603 Zhejiang
P.R. China

Ref : R TÜV-Mark Approval

Type of Equipment : Switch-disconnector
Model Designation : See Certificate
Certificate No. : R 50504634 0001
Report No. : CN213IDH 002

Dear Chen chuihe,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body


Hao Zheng

cc: Zhejiang Chint Electrics Co., Ltd.

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询