


Ref. Certif. No.

**SE-106072**

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**

**CB TEST CERTIFICATE**

Product	Switch-disconnectors
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No.1 Chint Road, Chint Industrial Zone North Baixiang, Yueqing Zhejiang Province, P.R.China
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	See page 2
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	NH2-125
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 60947-3:2020
As shown in the Test Report Ref. No. which forms part of this Certificate	210702728SHA-001, -002, -003, -004

This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden



Signature: *Quan Li*

Date: 08 October, 2021

Quan Li

**Ratings and principal characteristics**

$U_e=230V(1P), 400V(2,3,4P), 50/60Hz$

$I_e=32, 63, 100, 125A, \text{Cat. AC-22A}$

$U_i=500V, U_{imp}=4kV$

$I_{cw}=12I_e/1s, I_{cm}=20I_e.$

NH2-125, rated  $I_e=32A, 63A$  and  $I_e=100A, 125A$  are not the same frame size

Date: 08 October, 2021

Signature: *Amelia*