



Ref. Certif. No.

SE-89475

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch-disconnectors

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
Zhejiang Province, P.R.China. 325603

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

Ue=230V(1P), 400V(2P, 3P, 4P), 50/60Hz
Ie=32A, 63A, 100A, 125A, Cat. AC-22A
Ui=500V, Uimp=4kV
Icw=12Ie/1s, Icm=20Ie.

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NH2-125

Additional information (if necessary may also be reported on page 2)

For model NH2-125: rated Ie=32A,63A and Ie=100A,125A are not the same frame size

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2008+A1+A2

As shown in the Test Report Ref. No. which forms part of this Certificate

171101813SHA-001, -002, -003, -004

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00



Signature:

Bo Berglöf

Date: 3 January 2018