




Ref. Certif. No.

SE-89368

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE


Product	Switch-disconnectors
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang. Yueqing, Zhejiang Province, P.R. CHINA 325603
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	Ue= 240V~(1P), 415V~(2P, 3P, 4P) Ie= 32, 40, 63, 80, 100, 125A Icw= 12Ie, 1s; Icm= 20Ie; Cat. AC-22A 50/60Hz
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	NH4-125
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 60947-3:2008+A1+A2
As shown in the Test Report Ref. No. which forms part of this Certificate	17101849SHA-001, 17101849SHA-002, 17101849SHA-003, 17101849SHA-004

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 20 December 2017



Signature: 

Fredrik Wennersten