

NJB1-X Voltage Protection Relay

## **User Instruction**

## **★** Safety Warning

- Only professional technicians are allowed for installation and maintenance.
- ② Installation in any damp, condensed-phase environment with inflammable and explosive gas is forbidden.
- 3 When the product is being installed or maintained, the power must be switched off.
- 4 You are prohibited from touching the conductive part when the product is operating.
- 5 The product shall be stored, installed and used in accordance with the rated control power supply voltage and specified conditions indicated in the user instructions.

## Use Purpose

Used as the phase sequence, phase loss and three-phase voltage unbalance protection component to connect or disconnect the circuit, NJB1-X voltage protection relay (hereinafter referred to as the relay) is applicable to the control circuit with AC frequency of 50Hz/60Hz and rated control power voltage of AC380V~AC480V.

## 2 Key Technical Parameters

### **Table 1 Ambient Conditions**

| Normal use conditions               | Ambient temp.: -5°C~+40°C; average value within 24h not exceeding +35°C; altitude not exceeding 2,000m.   |
|-------------------------------------|---|
| Atmospheric conditions              | RH shall not exceed 50% when maximum temperature is +40°C;<br>in case of lower temperature, higher RH is allowed. Measures<br>should be taken against occasional condensation due to<br>temperature change. |
| Installation<br>category            | п   |
| Transport and<br>storage conditions | -25°C~+55°C   |

| Table 2 Product Specifications and Main Technical Parameters |                                |   |                               |  |
|--|--------------------------------|---|-------------------------------|--|
| Model  | NJB1-X                         |   |                               |  |
| Installation method  | Rail mounting, Equipment type  |   |                               |  |
| Protection function  | Phase loss, phase sequence Thi |   | Three-phase voltage unbalance |  |
| Motion time  | ≤0.1s                          |   | 0.1s~30s                      |  |
|  | Motion value setting range     | Unbalance rate: 2%~22%  |                               |  |
|  | Motion value                   | 100% motion at set value  |                               |  |
| Unbalance motion<br>(ASY)                                    | Unbalance motion condition     | Unbalance motion value = rated input<br>voltage × unbalance set value (%)<br>When the difference between the<br>highest phase voltage and the lowest<br>phase voltage is equal to or exceeds<br>the unbalance motion value, the<br>unbalance motion will work |                               |  |
| Reset (HYS)  | Lag                            | 25% lower than the set motion val-<br>and after delay of 0.5s   |                               |  |
|  | Reset method                   | Auto reset  |                               |  |

**Table 3 Main Circuit and Auxiliary Circuit Technical Parameters** 

| No. | Product model  | NJB1-X  |        |  |
|-----|--|---|--------|--|
| 1   | Rated control supply voltage Us (V), frequency (Hz)                  | Three-phase three-wire system:<br>AC380V,AC400V,AC415V,<br>AC480V,50Hz/60Hz<br>Three-phase four-wire system:<br>AC220V,AC230V,AC240V,<br>AC277V,50Hz/60Hz |        |  |
| 2   | Allowable fluctuation range of rated control<br>power supply voltage | 85%Us~110%Us  |        |  |
| 3   | Agreed free air heating current Ith (A)                              | 3   |        |  |
| 4   | Rated operating voltage Ue (V)                                       | AC240V  | AC415V |  |
| 5   | Use type under rated operating voltage and                           | AC-15   | AC-15  |  |
| l ° | rated operating current Ie(A)  | 0.75A   | 0.47A  |  |
| 6   | Rated insulation voltage Ui (V)                                      |   | AC500V |  |
| 7   | Rated impulse withstand voltage Uimp (kV)                            | 4   |        |  |
| 8   | Enclosure protection class (if applicable)                           | IP20  |        |  |
| 9   | Pollution class  | Class 3   |        |  |
| 10  | Type and maximum value of short circuit protection RT36-00/4A        |   | 00/4A  |  |
| 11  | Size of terminal tightening screw (or nut)                           | M3  |        |  |
| 12  | Torque of terminal tightening screw (N·m) 0.5                        |   | .5     |  |
| 13  | Electrical life / mechanical life (10,000 times)                     | times) 10/100   |        |  |

**Table 4 Immunity to Interference** 

| No. | Test type                                     | Test level                        |  |
|-----|---|-----------------------------------|--|
| 1   | Electrostatic discharge immunity test         | 8kV (air discharge)               |  |
| 2   | RF electromagnetic field immunity test        | 10V/m                             |  |
| 3   | Electrical fast transient/burst immunity test | 2kV/5kHz on the power supply side |  |
| 4   | Surge immunity test                           | 1kV (wire to wire)                |  |

## **B** Installation

3.1 Outline and installation size: see Figure 1, unit: mm.



Figure 1 Outline and Installation Size

**3.2** Panel diagram: see Figure 2; selection switch position diagram: see Figure 3; working mode setting: see Table 5, Table 6; wiring diagram: see Figure 4; working sequence diagram: see Figure 5.




Figure 2 Panel Diagram




Figure 3 Selection Switch Position Diagram

Table 5 Working Mode Setting 1

|       | Function                 |     |                                       | Default |  |
|-------|--------------------------|-----|---------------------------------------|---------|--|
| Key 1 | Power ON lock time       | ON  | T1=5s                                 | OFF     |  |
|       |                          | OFF | T1=1s                                 |         |  |
| Key 2 | Wiring mode<br>selection | ON  | Three-phase four-wire<br>system mode  | OFF     |  |
|       |                          | OFF | Three-phase three-wire<br>system mode | OFF     |  |

**Table 6 Working Mode Setting 2** 

| Table 6 Working Wode Setting 2 |     |                                    |                                  |         |     |  |
|--------------------------------|-----|------------------------------------|----------------------------------|---------|-----|--|
|                                |     | Rated control power supply voltage |                                  |         |     |  |
| Key 3 Key 4                    |     | Three-phase three<br>-wire system  | Three-phase four<br>-wire system | Default |     |  |
| OFF                            | OFF | AC380V                             | AC220V                           |         |     |  |
| ON                             | OFF | AC400V                             | AC230V                           | OFF     | OFF |  |
| OFF                            | ON  | AC415V                             | AC240V                           | OFF     | UFF |  |
| ON                             | ON  | AC480V                             | AC277V                           |         |     |  |





Figure 4 Wiring Diagram



### Notes:

- The nameplate is a schematic scale, and the protection motion value should be checked during use.
- 2) Turning the knob or changing the state of the setting switch during the protection process will lead to the incorrect delay time of this motion. The setting should be completed in normal operating state or before power is applied.
- 3) T1: Power lock time (1s or 5s); T: motion time (0.1s~30s).
- 4) During use, the time interval from power cut to voltage reapplication must be greater than 1s, otherwise the reset may be unreliable.
- 5.) At the time of phase sequence motion protection, the alarm indicator light flashes at an interval of about 1s; In the unbalance motion protection process, the alarm indicator light flashes at an interval of 1s or so, after motion, the alarm indicator light will be normally on.
- 6) The product is compatible with three-phase four-wire and three-phase three-wire wiring modes. After the product is installed, please confirm the position of the wiring mode dial switch is correct, so as to avoid malfunction of the product.
- 7) In the three-phase four wire mode, the phase loss fault of the neutral wire can be measured, but the leakage fault of the neutral wire cannot be detected.

- 8 ) Phases L1 and L2 are the auxiliary power supplies of the product. In case of phase loss fault of L1 and L2, the normally open contact of the relay is disconnected and all indicator lights are off.
- 9 ) The power supply input line should not be in the same pipe or twisted with other wires with strong current. If necessary, please use shielded wire which should be as short as possible to avoid interference and affecting the normal operation of the relay.

### 4 Maintenance

- 4.1 The terminal of the relay should be tightened on a regular basis.
- **4.2** Avoid squeezing the product; the product should be stored in a well-ventilated place.

Table 7 Fault Analysis and Troubleshooting

| Symptoms Cause analysis                            |   | Troubleshooting method   |  |  |
|--|---|--|--|--|
| The power indicator light is not on after power on | The power supply pin is not wired and the wiring is incorrect or disconnected. The product is not electrified or the control power supply voltage does not match the rated control power supply voltage of the product. | Select the power supply voltage that matches the rated control power supply voltage of the product and connect wires reliably according to the user instructions.  |  |  |
| Abnormal<br>operation<br>after<br>power on         | The control wiring of the relay is incorrect or disconnected, whether the input voltage is too low, whether the settings of the working mode and the knobs meet the requirements.                                       | Set the working mode and the knobs of the product according to the user instructions, select the power supply voltage corresponding to the rated control power supply voltage set by the product and connect wires reliably. |  |  |

## 

In order to protect the environment, the product or product parts should be disposed of according to the industrial waste treatment process, or be sent to the recycling station for assortment, dismantling and recycling according to local regulations.

## **CHNT**

# **QC PASS**

NJB1-X

Voltage Protection Relay IEC/EN 60947-5-1

(JDQ Check 10)

Test date: Please see the packing

ZHEJIANG CHINT ELECTRICS CO., LTD.



NJB1-X Voltage Protection Relay User Instruction

### Zhejiang Chint Electrics Co., Ltd.

Add: No.1, CHINT Road, CHINT Industrial Zone,North Baixiang, Yueqing, Zhejiang 325603,P.R.China

E-mail: global-sales@chint.com Website: http://en.chint.com





