



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE210307007216

Product Soft Starter

Applicant Zhejiang CHINT Electric Co., Ltd.
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model NJR5-110/ZX2, NJR5-110/ZX3, NJR5-110/ZX4,
NJR5-110/ZX5, NJR5-110/ZX6, NJR5-150/ZX2,
NJR5-150/ZX3, NJR5-150/ZX4, NJR5-150/ZX5,
NJR5-150/ZX6;

Technical data See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
00901-CE2020CQC0307-011504, the submitted sample(s) of the above item complies
with:

EN 60947-4-2:2012

and fulfills testing requirements of the European Directive:
2014/35/EU

Valid from: May.07,2021

Valid until: May.07,2024

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

CE 0011441



CHINA QUALITY CERTIFICATION CENTRE

CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE210307007216

NJR5-110/ZX2, NJR5-110/ZX3, NJR5-110/ZX4, NJR5-110/ZX5, NJR5-110/ZX6,
NJR5-150/ZX2, NJR5-150/ZX3, NJR5-150/ZX4, NJR5-150/ZX5, NJR5-150/ZX6
Uimp: 8kV;
Ui: 660V (NJR5-110/ZX2, NJR5-150/ZX2, NJR5-110/ZX3, NJR5-150/ZX3), 1000V
(NJR5-110/ZX4, NJR5-150/ZX4, NJR5-110/ZX5, NJR5-150/ZX5, NJR5-110/ZX6,
NJR5-150/ZX6);
Ith: 103A (NJR5-110/ZX2, NJR5-110/ZX3, NJR5-110/ZX4, NJR5-110/ZX5,
NJR5-110/ZX6), 140A (NJR5-150/ZX2, NJR5-150/ZX3, NJR5-150/ZX4,
NJR5-150/ZX5, NJR5-150/ZX6);
Ue: AC220V (NJR5-110/ZX2, NJR5-150/ZX2), AC380V (NJR5-110/ZX3,
NJR5-150/ZX3), AC460V (NJR5-110/ZX4, NJR5-150/ZX4), AC575V
(NJR5-110/ZX5, NJR5-150/ZX5), AC690V (NJR5-110/ZX6, NJR5-150/ZX6);
Ie: 103A (NJR5-110/ZX2, NJR5-110/ZX3, NJR5-110/ZX4, NJR5-110/ZX5,
NJR5-110/ZX6), 140A (NJR5-150/ZX2, NJR5-150/ZX3, NJR5-150/ZX4,
NJR5-150/ZX5, NJR5-150/ZX6);
Pe: 30kW(NJR5-110/ZX2), 37kW(NJR5-150/ZX2), 55kW(NJR5-110/ZX3),
75kW(NJR5-150/ZX3, NJR5-110/ZX4, NJR5-110/ZX5), 90kW(NJR5-150/ZX4),
110kW(NJR5-150/ZX5, NJR5-110/ZX6), 132kW(NJR5-150/ZX6);
Utilization category: AC-53a;
3P;
IP20

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>