



CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Certificate No.: CE240307008985

Product

Soft Starter

Applicant

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Type/Model

NJRP5-15/D6,NJRP5-22/D6,NJRP5-30/D6,NJRP5-37/D6,NJRP5-44/D6,NJRP5-60/D6,
NJRP5-74/D6,NJRP5-90/D6,NJRP5-15/D4,NJRP5-22/D4,NJRP5-30/D4,NJRP5-37/D4,
NJRP5-44/D4,NJRP5-60/D4,NJRP5-74/D4,NJRP5-90/D4;

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2024CQC0307-014666, the submitted sample(s) of the above item complies with:

EN IEC 60947-4-2:2023

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Jun.26,2024

Valid until: May.19,2027

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 3

Certificate No.: CE240307008985

NJRP5-15/D6,NJRP5-22/D6,NJRP5-30/D6,NJRP5-37/D6,NJRP5-44/D6,NJRP5-60/D6,
NJRP5-74/D6,NJRP5-90/D6,NJRP5-15/D4,NJRP5-22/D4,NJRP5-30/D4,NJRP5-37/D4,
NJRP5-44/D4,NJRP5-60/D4,NJRP5-74/D4,NJRP5-90/D4

Uimp: 8kV;

Ui: See Table 1;

Ith: See Table 1;

Ue: See Table 1;

Ie: See Table 1;

Pe: See Table 1;

AC-53b;

Pole:3P;

IP20

Table 1

Type	Pe	Ith	Ie	Ue	Ui
NJRP5-15/D6	4kW (Ue=AC220V)	15A	15A	AC200V-AC690V	1000V
	7.5kW (Ue=AC380V)				
	9kW (Ue=AC460V)				
	11kW (Ue=AC575V)				
	11kW (Ue=AC690V)				
NJRP5-22/D6	5.5kW (Ue=AC220V)	22A	22A		
	11kW (Ue=AC380V)				
	15kW (Ue=AC460V)				
	18.5kW (Ue=AC575V)				
	18.5kW (Ue=AC690V)				
NJRP5-30/D6	7.5kW (Ue=AC220V)	29A	29A		
	15kW (Ue=AC380V)				
	18.5kW (Ue=AC460V)				
	22kW (Ue=AC575V)				
	22kW (Ue=AC690V)				
NJRP5-37/D6	11kW (Ue=AC220V)	36A	36A		
	18.5kW (Ue=AC380V)				



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 3

Certificate No.: CE240307008985

	22kW (Ue=AC460V)				
	30kW (Ue=AC575V)				
	30kW (Ue=AC690V)				

Type	Pe	Ith	Ie	Ue	Ui
NJRP5-44/D6	11kW (Ue=AC220V)	42A	42A	AC200V-AC690V	1000V
	22kW (Ue=AC380V)				
	30kW (Ue=AC460V)				
	30kW (Ue=AC575V)				
	37kW (Ue=AC690V)				
NJRP5-60/D6	15kW (Ue=AC220V)	57A	57A		
	30kW (Ue=AC380V)				
	37kW (Ue=AC460V)				
	45kW (Ue=AC575V)				
	55kW (Ue=AC690V)				
NJRP5-74/D6	18.5kW (Ue=AC220V)	70A	70A		
	37kW (Ue=AC380V)				
	45kW (Ue=AC460V)				
	55kW (Ue=AC575V)				
	75kW (Ue=AC690V)				
NJRP5-90/D6	22kW (Ue=AC220V)	84A	84A		
	45kW (Ue=AC380V)				
	55kW (Ue=AC460V)				
	75kW (Ue=AC575V)				
	90kW (Ue=AC690V)				
NJRP5-15/D4	4kW (Ue=AC220V)	15A	15A	AC200V-AC415V	660V
	7.5kW (Ue=AC380V)				
	7.5kW (Ue=AC415V)				
NJRP5-22/D4	5.5kW (Ue=AC220V)	22A	22A		



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

CERTIFICATE OF CONFORMITY

Appendix

Page 3 of 3

Certificate No.: CE240307008985

	11kW (Ue=AC380V)				
	11kW (Ue=AC415V)				
NJRP5-30/D4	7.5kW (Ue=AC220V)	29A	29A		
	15kW (Ue=AC380V)				
	15kW (Ue=AC415V)				
NJRP5-37/D4	11kW (Ue=AC220V)	36A	36A		
	18.5kW (Ue=AC380V)				
	18.5kW (Ue=AC415V)				

Type	Pe	Ith	Ie	Ue	Ui
NJRP5-44/D4	11kW (Ue=AC220V)	42A	42A	AC200V-AC415V	660V
	22kW (Ue=AC380V)				
	22kW (Ue=AC415V)				
NJRP5-60/D4	15kW (Ue=AC220V)	57A	57A		
	30kW (Ue=AC380V)				
	30kW (Ue=AC415V)				
NJRP5-74/D4	18.5kW (Ue=AC220V)	70A	70A		
	37kW (Ue=AC380V)				
	37kW (Ue=AC415V)				
NJRP5-90/D4	22kW (Ue=AC220V)	84A	84A		
	45kW (Ue=AC380V)				
	45kW (Ue=AC415V)				



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE