

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

## Product

Type B residual current operated circuit-breakers (RCCBs)

## Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.  
No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603  
Zhejiang  
China

## Name and address of the manufacturer

Zhejiang Chint Electrics Co., Ltd.  
No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603  
Zhejiang  
China

## Name and address of the factory

Zhejiang Chint Electrics Co., Ltd.  
No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603  
Zhejiang  
China

*Note: When more than one factory, please report on page 2*

Additional information on page 2

## Ratings and principal characteristics

2P, 4P  
Ue: 230 / 240 Vac for 2P, 400 / 415 Vac for 4P  
In: 25, 40, 63 A, 50 Hz, IΔn: 0,03, 0,1, 0,3 A  
Type B (Including type A and AC), without time-delay  
Inc = IΔc = 10 kA, Im = IΔm: 500 A or 10 In (whichever is greater)  
The grid distance "a": 50 mm

## Trademark / Brand (if any)

CHINT

## Customer's Testing Facility (CTF) Stage used

## Model / Type Ref.

NL210

## Additional information (if necessary may also be reported on page 2)

Ambient air temperature: - 25 °C ... + 40 °C (-25°C was tested according to EN 62423:2012 / EN 61008-1:2012).  
This certificate replaces certificate CB no. NL-85942 issued on 2023-02-13.  
The tests were performed in 2016, 2019, 2020, 2022 and 2023.

Additional information on page 2

## A sample of the product was tested and found to be in conformity with

IEC 61008-1:2010, IEC 61008-1:2010/AMD1:2012, IEC 61008-1:2010/AMD2:2013, IEC 61008-2-1:1990, IEC 62423:2009

## National differences:

AU, BE

## As shown in the Test Report Ref. No. which forms part of this Certificate

3328235.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051  
Arnhem, 6825 MJ  
Netherlands



Date: 2023-07-06

Signature: F.S.Strikwerda