

IEC

IECEE



TM

Ref. Certif. No.

CN56868

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Moulded Case Circuit-breaker
Name and address of the applicant	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the manufacturer	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Name and address of the factory	NOARK Electrics (Shanghai) Co., Ltd. No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	See the attachment
Trademark / Brand (if any)	CHINT
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	NM3DC-400HV, NM3DC-630HV
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016/AMD1:2019; IEC 60947-2:2016(5th Edition)
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2022CQC-101247

This CB Test Certificate is issued by the National Certification Body

## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: May.17,2022

Signature:

谢肇煦

Xie ZhaoXu



CB 0069322



NM3DC-400HV, NM3DC-630HV

U<sub>imp</sub>: 12kV;

U<sub>i</sub>: 1500V;

U<sub>e</sub>: DC1500V;

I<sub>n</sub>: NM3DC-400HV: 200A, 225A, 250A, 280A, 300A, 315A, 350A, 400A;

NM3DC-630HV: 200A, 225A, 250A, 280A, 300A, 315A, 350A, 400A, 450A, 500A, 550A, 630A;

Over-current release type: Thermal-magnetic;

I<sub>cs</sub>: 15kA;

I<sub>cu</sub>: 15kA;

Selectivity category: A;

Suitable for isolation;

2P appearance;

Auxiliary contact: AX40-M3DC, AL40-M3DC, AXL40-M3DC, SHTA40-M3DC, SHTB40-M3DC;

1NO1NC;


I<sub>th</sub>: 5A;

AC-15: U<sub>e</sub>/I<sub>e</sub>: AC110V/5A, AC240V/4A, AC415V/2A;

DC-13: U<sub>e</sub>/I<sub>e</sub>: DC110V/0.25A, DC220V/0.25A;

Connection diagram:

+ ( - ) - ( + )



Load

DC 1500V

Page 1 of 2

Additional information (if necessary)

Date: May.17,2022

Signature:

谢肇旭  
Xie ZhaoXu



**Type explanation:**NM3 DC - ☐ HV E

① ② ③ ④ ⑤

① General code for MCCB

② Code for DC

③ Code for frame size current: 400, 630

④ Code for high-voltage

⑤ Code for breaking capacity: F

Page 2 of 2

Additional information (if necessary)

Date: May.17,2022

Signature:

谢肇煦

Xie ZhaoXu