

IEC

IECEE



TM

Ref. Certif. No.

CN55907-A1/M2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded Case Circuit-breaker

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

NOARK Electrics (Shanghai) Co., Ltd.
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NM8N-250HV;

Additional information (if necessary may also be
reported on page 2)The latest CB certificate No. is CN55907-A1/M1, dated
2022-05-05. The issuance of the M2 certificate is to change
parameters.A sample of the product was tested and found
to be in conformity withIEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016(5th
Edition);IEC 60947-1:2007;IEC
60947-1:2007/AMD1:2010;IEC 60947-1:2007/AMD2:2014As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2021CQC-100552-A1/M2

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Mar.12,2024

Signature:

谢肇煦

Xie ZhaoXu



NM8N-250HV

Uimp: 8kV;

Ui: 1250V;

Ue: AC690V, AC800V, AC1000V, AC1140V, AC1150V;

In: 10A, 16A, 20A, 32A, 40A, 50A, 63A, 80A, 100A, 125A, 160A, 180A, 200A, 225A, 250A;

Over-current release type: Thermal-magnetic, Electromagnetic;

Ics: Type C: AC690V: 50kA, AC800V: 36kA, AC1000V: 15kA, AC1140V: 10kA, AC1150V: 10kA;

Type S: AC690V: 80kA, AC800V: 50kA, AC1000V: 15kA, AC1140V: 10kA, AC1150V: 10kA;

Icu: Type C: AC690V: 50kA, AC800V: 36kA, AC1000V: 15kA, AC1140V: 10kA, AC1150V: 10kA;

Type S: AC690V: 80kA, AC800V: 50kA, AC1000V: 30kA, AC1140V: 10kA, AC1150V: 10kA;

Selectivity category: A;

3P;

Suitable for isolation;

50/60Hz;

Auxiliary contact: AX21-M8, AL21-M8

1NO1NC;

Ith: 5A;

AC-15: Ue/Ie: AC110V/5A, AC240V/4A, AC415V/2A;

DC-13: Ue/Ie: DC110V/0.25A, DC220V/0.25A;

Electronic accessories complied with Annex N:

Undervoltage release: UVT22HV-M8: Us: AC48V 50/60Hz, AC110V 50/60Hz, AC220~240V 50/60Hz, AC380~415V 50/60Hz, DC24V, DC48V, DC110~120V, DC220V

Mtor-operator: MOD22HV-M8:

Us: AC110V 50/60Hz, AC220-240V 50/60Hz, AC380-415V 50/60Hz, DC110V, DC220V, DC24V

Page 1 of 1

Additional information (if necessary)

Date:

Mar.12,2024

Signature:

谢肇煦
Xie ZhaoXu