ATTESTATION OF CONFORMITY

Issued to:	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang, China			
For the product:	Moulded-case circuit-breaker			
Trade name:	CHINT			
Type/Model:	NM8NDC-630B, NM8NDC-630C, NM8NDC-630S, NM8NDC-630Q, NM8NDC-630H, NM8NDC-400B, NM8NDC-400C, NM8NDC-400S, NM8NDC-400Q, NM8NDC-400H			
Ratings:	Ue: 1000 Vdc for 4P, 750 Vdc for 3P, In: 250 A, 315 A, 350 A, 400 A, 500 A See annex for further ratings			
Manufactured by:	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang, China			
Subject:	Type test			
Requirements:	EN 60947-2:2017, EN 60947-2:2017/A1:2020, EN 60947-5-1:2017, IEC 60947-2:2016, /EC 60947-2:2016/A1:2019, /EC 60947-5-1:2016			
Remark:	This attestation replaces no. 3315353.01A issued on 2019-10-11.			

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a test reports no. 3321431.50 issued on 2022-03-25, CQC/CB/test/report no. 00901-CB2018CQC-084130 issued on 2019-03-25 with CB test certificate no. CN46412 issued on 2019-04-09 and CQC/CB test report no. 00901-CB2018CQC-084130-M1 issued on 2019-06-06 with CB test certificate no. CN46412-M1 issued on 2019-06-18.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective/EC directives are complied with. Wenzhou, Zhejiang, 07 April 2022 Number: 3321431.01A

DEKRA Testing Services (Zhejiang) Co., Ltd.

Ms J Guo Certification Manager

© Integral publication of this attestation and adjoining reports is allowed



DEKRA Testing Services (Zhejiang) Co., Ltd. No. 5, Changjiang Road, Great Bridge Industrial Park, North Baixiang, 325603 Wenzhou, Zhejiang, China T +86 57762 868000 F +86 57762 919889 www.dekra-certification.com

ANNEX TO ATTESTATION OF CONFORMITY 3321431.01A



Ratings		
Number of poles		3P and 4P
Rated operational voltage (Ue)		1000 Vdc for 4P, 750 Vdc for 3P
Rated insulation voltage (Ui)	•	1000 V for main circuit
		500 V for control circuit
Detections de suittentes du statement		500 V for auxiliary circuit
Rated impulse withstand voltage	:	12 kV for main circuit
(Uimp)		2,5 kV for shunt release and undervoltage release
		6 kV for electric operating mechanism
		2,5 kV for auxiliary circuit
Conventional thermal current (Ith)	÷	Equal to In
Suitable for photovoltaic (PV)		Suitable
systems		Quite ble
Suitable for isolation	÷	Suitable
Selectivity category	÷	A
Safety distance (screen-circuit	÷	Front / back: 0 mm
breaker)		Left / right: 0 mm
		Up / down: 0 mm
Reference temperature	÷	40 °C
Method of mounting	÷	Fixed
EMC Environment	÷	A 25.0 Nm for M10
Tightening torque for terminals Line/load terminal	÷	25,0 Nm for M10 Immaterial
	÷	
Connection	:	copper conductor with cable lug Ir (inverse time delay tripping setting):
Inverse time delay release	·	Ir: $(0,7 / 0,8 / 0,9 / 1) \times \ln 0$
Time setting of the inverse time		Fixed, trip time at 2 ln: $60 \text{ s} \le t \le 600 \text{ s}$
delay release		Theu, the time at 2 m : $00.3 \pm 1 \pm 000.3$
Instantaneous release		li (instantaneous tripping setting):
	•	li: (5 / 6 / 7 / 8 / 9 / 10) x ln
Shunt release		SHT22-M8:
	•	AC: 48 V, 110 V, 220 - 240 V, 380 - 415 V, 50 / 60 Hz
		DC: 24 V, 48 V, 110 - 120 V, 220 V
Under-voltage release	•	UVT22-M8:
	•	AC: 48 V, 110 V, 220 - 240 V, 380 - 415 V, 50 / 60 Hz
		DC: 24 V, 48 V, 110 - 120 V, 220 V
Electric operating mechanism	:	MOD23-M8:
1 3		AC: 110 V, 220 - 240 V, 380 - 415 V, 50 / 60 Hz
		DC: 24 V, 110 V, 220 V
Auxiliary circuits		AX21-M8 / AL21-M8
		1 NO and 1 NC
		AC-15: 2 A at 415 Vac, 4 A at 240 Vac,
		5 A at 110 Vac
		DC-13: 0,25 A at 110 Vdc / 220 Vdc
		Ui: 500 V, Uimp: 2,5 kV
		Rated conditional short-circuit current: 1 kA
		Fuse: RL6-25/6, 6 A, 500 Vac, 50 kA, Schneider

Product rating - NM8NDC-630B

Rated current (In) Rated ultimate short-circuit breaking capacity (Icu) Rated service short-circuit breaking capacity (Ics)	:	250 A, 315 A, 350 A, 400 A, 500 A 25 kA at 1000 Vdc for 4P, 25 kA at 750 Vdc for 3P 25 kA at 1000 Vdc for 4P, 25 kA at 750 Vdc for 3P
Product rating - NM8NDC-630C Rated current (In) Rated ultimate short-circuit breaking capacity (Icu) Rated service short-circuit breaking capacity (Ics)	:	250 A, 315 A, 350 A, 400 A, 500 A 36 kA at 1000 Vdc for 4P, 36 kA at 750 Vdc for 3P 36 kA at 1000 Vdc for 4P, 36 kA at 750 Vdc for 3P
Product rating - NM8NDC-630S Rated current (In) Rated ultimate short-circuit breaking capacity (Icu) Rated service short-circuit breaking capacity (Ics)	:	250 A, 315 A, 350 A, 400 A, 500 A 50 kA at 1000 Vdc for 4P, 50 kA at 750 Vdc for 3P 50 kA at 1000 Vdc for 4P, 50 kA at 750 Vdc for 3P,
Product rating - NM8NDC-630Q Rated current (In) Rated ultimate short-circuit breaking capacity (Icu) Rated service short-circuit breaking capacity (Ics)	:	250 A, 315 A, 350 A, 400 A, 500 A 70 kA at 1000 Vdc for 4P, 70 kA at 750 Vdc for 3P, 70 kA at 1000 Vdc for 4P, 70 kA at 750 Vdc for 3P,
Product rating - NM8NDC-630H Rated current (In) Rated ultimate short-circuit breaking capacity (Icu) Rated service short-circuit breaking capacity (Ics)	:	250 A, 315 A, 350 A, 400 A, 500 A 100 kA at 1000 Vdc for 4P, 100 kA at 750 Vdc for 3P, 100 kA at 1000 Vdc for 4P, 100 kA at 750 Vdc for 3P,
Product rating - NM8NDC-400B Rated current (In) Rated ultimate short-circuit breaking capacity (Icu) Rated service short-circuit breaking	:	250 A, 315 A, 350 A, 400 A 25 kA at 1000 Vdc for 4P, 25 kA at 750 Vdc for 3P 25 kA at 1000 Vdc for 4P,
capacity (Ics)	•	25 kA at 750 Vdc for 3P
Product rating - NM8NDC-400C Rated current (In) Rated ultimate short-circuit breaking capacity (Icu) Rated service short-circuit breaking capacity (Ics)	:	250 A, 315 A, 350 A, 400 A 36 kA at 1000 Vdc for 4P, 36 kA at 750 Vdc for 3P 36 kA at 1000 Vdc for 4P, 36 kA at 750 Vdc for 3P

DEKRA

Product rating - NM8NDC-400S

Troduct rating - Minorado-4000		
Rated current (In)	:	250 A, 315 A, 350 A, 400 A
Rated ultimate short-circuit	:	50 kA at 1000 Vdc for 4P,
breaking capacity (Icu)		50 kA at 750 Vdc for 3P
Rated service short-circuit breaking	:	50 kA at 1000 Vdc for 4P,
capacity (Ics)		50 kA at 750 Vdc for 3P,
Product rating - NM8NDC-4000		

Product rating - NM8NDC-400Q

Rated current (In) Rated ultimate short-circuit breaking capacity (Icu) Rated service short-circuit breaking : 70 kA at 1000 Vdc for 4P, capacity (Ics)

Product rating - NM8NDC-400H

Rated current (In)	:	250 A, 315 A, 350 A, 400 A
Rated ultimate short-circuit	:	100 kA at 1000 Vdc for 4P,
breaking capacity (Icu)		100 kA at 750 Vdc for 3P,
Rated service short-circuit breaking	:	100 kA at 1000 Vdc for 4P,
capacity (Ics)		100 kA at 750 Vdc for 3P,

Additional information

NM8N	<u>I DC</u> –	- <u>630</u>	<u>C</u>	TΜ	<u>500</u>	<u>) 4</u>	
а	b	С	d	е	f	g	

a = model name: 'NM8N'

b = direct current: 'DC'

c = frame size: '630' or '400'

d = short-circuit capacity: 'B', 'C', 'S', 'Q' or 'H'

e = trip unit: 'TM' means thermal magnetic type

f = rated current: 250 A, 315 A, 350 A, 400 A, 500 A

g = number of poles: '4' means 4P, '3' means 3P

Accessory type	Model
Auxiliary circuit	AX21-M8 / AL21-M8
Shunt release	SHT22-M8
Under-voltage release	UVT22-M8
Electric operating mechanism	MOD23-M8
Rotation handle	DRH23-M8

: 250 A, 315 A, 350 A, 400 A

70 kA at 750 Vdc for 3P,

70 kA at 750 Vdc for 3P,

: 70 kA at 1000 Vdc for 4P,

DEKRA