

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Thermal overload relay
Name and address of the applicant	Zhejiang CHINT Electrics Co., Ltd. No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang, China
Name and address of the manufacturer	Zhejiang CHINT Electrics Co., Ltd. No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang, China
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 Zhejiang CHINT Electrics Co., Ltd. No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang, China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Main circuit: 50 / 60 Hz, $U_i=690$ V, $U_{imp}=6$ kV, $I_r=10$ kA, $I_q=50$ kA, type of co-ordination: "1" $U_e$ : 380 / 400 / 415 Vac, 660 Vac $I_e$ : 80-104 A, 95-120 A, 110-150 A Terminal: Flexible and rigid stranded wire: 10 mm <sup>2</sup> -50 mm <sup>2</sup> Terminations: One side, screw terminals, one conductor per terminal Other side, pins to be connected to contactors Auxiliary circuit: 1NO and 1NC, 50 / 60 Hz, $I_{th}=5$ A, $U_i=690$ V, $U_{imp}=6$ kV, AC-15: 1,58 A at 380 Vac, 2,73 A at 220 Vac, DC-13:0,2 A at 220 Vdc See annex for further ratings
Trademark (if any)	CHINT
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	NR2-150
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 This certificate replaces CB NL-37811 issued on 2015-10-19. The tests were performed in 2009, 2010, 2015 and 2019.
A sample of the product was tested and found to be in conformity with	IEC 60947-4-1:2018, IEC 60947-5-1:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	3316370.50 and 3316366.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands