ATTESTATION OF CONFORMITY

Issued to: Zhejiang Chint Electrics Co., Ltd.

No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueging,

325603 Zhejiang, China

For the product: Thermal overload relay

Trade name: CHINT

Type/Model: NR2-630

Ratings: 380 / 400 / 415 Vac, 660 Vac,

160-250 A, 200-315 A, 250-400 A, 315-500 A, 400-630 A

See annex for further ratings

Manufactured by: Zhejiang Chint Electrics Co. Ltd.

No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yveging,

325603 Zhejiang, China

Requirements: BS EN IEC 60947-4-1:2019, BS EN 60947-5-1:2017

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 3316372.50 issued on 2019-09-12 and 3316366.51 issued on 2019-09-05.

This Attestation implies that the examined types are in accordance with the standards designated under the Electrical Equipment (Safety) Regulations 2016.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The UKCA marking may be affixed on the product if all relevant and effective UK regulations are complied with.

DEKRA Testing Services (Zhejiang) Co., Ltd

J. Guo Certification Manager

© Integral publication of this attestation and adjoining reports is allowed





Annex

Document no. 3322005.01A

Ratings:

product Thermal Overload Relay

trade name(s) CHINT type(s) NR2-630

kind of equipment Thermal Overload Relay

number of poles kind of current (a.c. or d.c.) a.c interrupting medium Air

method of operation Automatic and by hand

rated frequency 50/60 Hz

rated duties Uninterrupted operation duty

Rated and limiting values, main circuit As below

rated operational voltage Ue (V) 380/400/415, 660 Vac

rated insulation voltage Ui (V) 690 V rated impulse withstand voltage Uimp(kV) 6 kV conventional free air thermal current Ith (A) 630 A

rated operational current le (A) or rated 160-250 A, 200-315 A, 250-400 A, 315-500 A,

400-630 A

operational powers

rated uninterrupted current lu (A) Equal to le 18 kA rated prospective short-circuit current "r" (kA)

rated conditional short-circuit current lq (kA) 50 kA type "1" co-ordination

type of co-ordination

SCPD

Manufacturer is CHINT

Terminal Prepared conductors (cable with lug):

 $35 \text{ mm}^2 - 2 \times 185 \text{ mm}^2$

Fuse: RT36-4 (NT4) gG 800 A, 690 Vac, 50 kA

As below **Auxiliary circuits**

rated operational voltage Ue (V) AC-15: 380 Vac, 220 Vac, DC-13: 220 Vdc

rated insulation voltage: Ui (V) 690 V rated impulse withstand voltage Uimp(kV) 6 kV

rated operational current: le (A) AC-15, 1,58 A at 380 Vac, 2,73 A at 220 Vac

DC-13, 0,2 A at 220 Vdc

kind of current AC or DC 50/60 Hz rated frequency: (Hz) number of circuits 2

1NO and 1NC number and kind of contact elements rated uninterrupted current: lu (A) Equal to le

utilization category: (AC, DC, current and AC-15, 1,58 A at 380 Vac, 2,73 A at 220 Vac

voltage) DC-13, 0,2 A at 220 Vdc

Short-circuit characteristic As below Rated conditional short-circuit current (kA) 1 kA

kind of protective device Fuse: RT36-00 (NT00)

6 A, 500 Vac, 120 kA Manufacturer is CHINT