



Ref. Certif. No.

CN57052

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Thermal Overload Relay
Name and address of the applicant	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province
Name and address of the manufacturer	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province
Name and address of the factory	Zhejiang CHINT Electrics Co., Ltd. No.2 Changjiang Road, CHINT Intelligent Electric Appliance Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Ui:690V; Uimp:6kV;Ue: AC690V; Ie: 0,10-0,14A,0,14-0,2A,0,18-0,25A,0,22-0,32A,0,28-0,4A,0,35-0,5A,0,45-0,63A,0,55-0,8A,0,7-1A, 0,9-1,25A,1,1-1,6A,1,4-2A,1,8-2,5A,2,2-3,2A,2,8-4A,3,5-5A,4,5-6,3A,5,5-8A,7,5-10A,9-13A,12- 16A, 14-20A,18-24A,23-32A,30-38A; Tripping class:10A; Number of poles:3P;IP20(Front side); Attached auxiliary contact (INOINC): Ui:690V; Uimp:6kV; Ith:5A; AC-15:Ue/Ie:AC380V/400V/1,5A, DC-13:DC220V/0,2A.
Trademark / Brand (if any)	CHINT
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	NR8-38;
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-4-1:2018;IEC 60947-5-1:2016(4th Edition)
As shown in the Test Report Ref. No. which forms part of this Certificate	03601-A-21CB0115-S-A;03601-A-21CB0115-S-B

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: http://www.cqc.com.cn



Date: May.25,2022

Signature:

谢肇煦

Xie ZhaoXu

CB 0068239