

Technical data

CERTIFICATE OF CONFORMITY **CERTIFICATE OF CONFORMITY**

Certificate No.: CE220305007982

Product Electronic Overload Relay

Applicant Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang

Town, Yueqing City, Zhejiang Province, P.R.China

NRE8-25; Type/Model

Ui:690V;Uimp:6kV;Ue:AC690V;Ie:0.6-1.2A,1.2-2.4A,2-4A

,4-8A,5-10A,7-12A,10-20A,20-25A,22-32A; Trip

class: 10A, 10, 20(3 options 1); 3P; IP20(Front Side); Auxiliary

contact:1NO1NC;Ith:5A; AC-15:

Ue/Ie:AC230V/2.5A,AC400V/1.5A;DC-13:

Ue/Ie:DC220V/0.2A

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2023CQC0305-013862, the submitted sample(s) of the above item complies with:

EN IEC 60947-4-1:2019

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Aug.16,2023

Valid until: Jan.03,2026

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE: 谢肇顺

