



Ref. Certif. No.

CN45895

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

AC Motor Starter

Name and address of the applicant

Zhejiang CHINT Electric Co., Ltd.  
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electric Co., Ltd.  
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Zhejiang CHINT Electric Co., Ltd.  
No.2 Changjiang Road, CHINT Intelligent Electric Appliance Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NS2-32H

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2009(3rd Edition) + AMD 1:2012;IEC 60947-2:2016(5th Edition)

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2018CQC-081854-1,00901-CB2018CQC-081854-2

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: http://www.cqc.com.cn



Date: Jan.25,2019

Signature:

Lu Mei

CB 0048937

NS2-32H;  
Uimp:8kV;  
Ui:690V;  
Ue:AC400/415V,AC690V;  
In:0.1-0.16A,0.16-0.25A,0.25-0.4A,0.4-0.63A,0.63-1A,1-1.6A,1.6-2.5A,2.5-4A,4-6.3  
A,6-10A,9-14A,13-18A,17-23A,20-25A,24-32A;  
Ue=AC400V/415V,  
Ics=100kA(0.1A-10A),25kA(9A-32A);  
Icu=100kA(0.1A-10A),50kA(9A-32A);  
Ue=AC690V,  
Ics=100kA(0.1-1.6A),4kA(1.6-32A);  
Icu=100kA(0.1-1.6A),4kA(1.6-32A);  
Over current release type: Thermal magnetic;  
Selectivity category:A,AC-3;Trip Class:10A;  
Poles:3P;  
Suitability for isolation

Page 1 of 1

Additional information (if necessary)

Date: Jan.25,2019

Signature: 

Lu Mei