

**IEC****IECEE**

®

TM

Ref. Certif. No.

CN55686-A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Air circuit breaker

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town,  
Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town,  
Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Wenzhou CHINT Electrics Technology Co., Ltd.  
No.1318, Binhai No.2 Avenue, Economic and Technical Development  
Zone, Wenzhou City, Zhejiang Province, P.R. China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NXA32N, NXA32S, NXA32H;

Additional information (if necessary may also be reported on page 2)

Original CB certificate No. is CN55686, dated 2021-12-23. The A1 modification is to correct the test report No. on certificate.

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016(5th Edition)

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-096952

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: May.17,2022

Signature:

谢肇旭

Xie ZhaoXu



CB 0068925

NXA32N,NXA32S,NXA32H

Uimp:12kV;

Ui:1000V;

Ue: AC380V/400V/415V, AC440V//525V/690V;

In: 1600A,2000A,2500A,3200A;

Over-current release: Electronic

Ics:

NXA32N: 80kA/AC380V/400V/415V, 65kA/AC440V/525V/AC690V;

NXA32S: 80kA/AC380V/400V/415V, 70kA/AC440V/525V/AC690V;

NXA32H: 85kA/AC380V/400V/415V, 70kA/AC440V/525V/AC690V;

Icu:

NXA32N: 80kA/AC380V/400V/415V, 65kA/AC440V/525V/AC690V;

NXA32S: 80kA/AC380V/400V/415V, 70kA/AC440V/525V/AC690V;

NXA32H: 100kA/AC380V/400V/415V, 70kA/AC440V/525V/AC690V;

Icw:

NXA32N: 65kA 1s/AC380V/400V/415V, 37kA 3s/AC380V/400V/415V, 65kA  
1s/AC440V/525V/AC690V;

NXA32S: 80kA 1s/AC380V/400V/415V, 50kA 3s/AC380V/400V/415V, 70kA  
1s/AC440V/525V/AC690V;

NXA32H: 85kA 1s/AC380V/400V/415V, 50kA 3s/AC380V/400V/415V, 70kA  
1s/AC440V/525V/AC690V;

Selectivity category:B;

3P,4P;

Suitability for insulation

50/60Hz;

Auxiliary contact (Body):

4NO4NC,6NO6NC;

Ui: 415V;

Ith: 6A;

Ue/Ie: AC-15: AC415V/0.75A, AC240V/1.3A;DC-13: DC220V/0.27A, DC110V/0.55A

Page 1 of 1

Additional information (if necessary)

Date: May.17,2022

Signature:

谢肇煦

Xie ZhaoXu