



Ref. Certif. No.

CN55655

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Air circuit breaker

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Wenzhou CHINT Electrics Technology Co., Ltd.  
No.1318, Binhai No.2 Avenue, Economic and Technical Development Zone, Wenzhou City, Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NXA20N,NXA20S,NXA20H;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016(5th Edition)

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-096397

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: http://www.cqc.com.cn



谢肇旭

Signature:

Xie ZhaoXu

CB 0066127

NXA20N,NXA20S,NXA20H;

Uimp:12kV;

Ui:1000V;

Ue: AC380V/400V/415V, AC440V//525V/690V;

In: 630A,800A,1000A,1250A,1600A,2000A;

Over-current release: Electronic

Ics:

NXA20N: 50kA/AC380V/400V/415V, 50kA/AC440V/525V/AC690V;

NXA20S: 65kA/AC380V/400V/415V, 55kA/AC440V/525V/AC690V;

NXA20H: 65kA/AC380V/400V/415V, 55kA/AC440V/525V/AC690V;

Icu:

NXA20N: 80kA/AC380V/400V/415V, 50kA/AC440V/525V/AC690V;

NXA20S: 65kA/AC380V/400V/415V, 55kA/AC440V/525V/AC690V;

NXA20H: 80kA/AC380V/400V/415V, 55kA/AC440V/525V/AC690V;

Icw:

NXA20N: 50kA 1s/AC380V/400V/415V, 37kA 3s/AC380V/400V/415V, 50kA  
1s/AC440V/525V/AC690V;

NXA20S: 65kA 1s/AC380V/400V/415V, 42kA 3s/AC380V/400V/415V, 55kA  
1s/AC440V/525V/AC690V;

NXA20H: 65kA 1s/AC380V/400V/415V, 42kA 3s/AC380V/400V/415V, 55kA  
1s/AC440V/525V/AC690V;

Selectivity category: B;

3P,4P;

Suitability for insulation

50/60Hz;

Auxiliary contact (Body):

4NO4NC,6NO6NC;

Ui: 415V;lth: 6A;

Ue/Ie: AC-15: AC415V/0.75A, AC240V/1.3A;

DC-13: DC220V/0.27A, DC110V/0.55A

Page 1 of 1

Additional information (if necessary)

Date: Dec.22,2021

Signature:

谢肇旭

Xie ZhaoXu