

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Air circuit breaker

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

Wenzhou CHINT Electrics Technology Co., Ltd.
No.1318, Binhai No.2 Avenue, Economic and Technical
Development Zone, Wenzhou City, Zhejiang Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NXA40S, NXA40H;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-2:2016/AMD1:2019; IEC 60947-2:2016(5th
Edition)

As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2021CQC-100588

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Dec.23,2021

Signature:

谢肇煦
Xie ZhaoXu



NXA40S, NXA40H

Uimp:12kV;

Ui:1000V;

Ue: AC380V/400V/415V, AC440V//525V/690V;

In: 3200A,3600A,4000A;

Over-current release: Electronic

Ics:

NXA40S: 85kA/AC380V/400V/415V, 75kA/AC440V/525V/AC690V;

NXA40H: 85kA/AC380V/400V/415V, 75kA/AC440V/525V/AC690V;

Icu:

NXA40S: 85kA/AC380V/400V/415V, 75kA/AC440V/525V/AC690V;

NXA40H: 100kA/AC380V/400V/415V, 75kA/AC440V/525V/AC690V;

Icw:

NXA40S: 85kA 1s/AC380V/400V/415V, 50kA 3s/AC380V/400V/415V, 75kA 1s/AC440V/525V/AC690V;

NXA40H: 85kA 1s/AC380V/400V/415V, 50kA 3s/AC380V/400V/415V, 75kA 1s/AC440V/525V/AC690V;

Selectivity category: B;

3P,4P;

Suitability for insulation

50/60Hz;

Auxiliary contact (Body):

4NO4NC,6NO6NC;

Ui: 415V;

Ith: 6A;

Ue/Ie: AC-15: AC415V/0.75A, AC240V/1.3A;DC-13: DC220V/0.27A, DC110V/0.55A

Page 1 of 1

Additional information (if necessary)

Date: Dec.23,2021

Signature:

谢肇煦
Xie ZhaoXu