

CERTIFICATE

Issued to:
Applicant:
Zhejiang Chint Electrics Co., Ltd.
No. 1, Chint Road, Chint Industrial Zone, North
Baixiang, Yueqing,
325603 Zhejiang, China

Licensee:
Zhejiang Chint Electrics Co., Ltd.
No. 1, Chint Road, Chint Industrial Zone, North
Baixiang, Yueqing,
325603 Zhejiang, China

Product : Air Circuit-Breaker
Trade name(s) : CHINT
Type(s)/model(s) : NXA32H, NXA32N and NXA32S

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard(s) EN 60947-2:2017, EN 60947-2:2017/A1:2020, IEC 60947-2:2016, IEC 60947-2:2016/A1:2019, IEC 60947-5-1:2016 and EN 60947-5-1:2017
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 2032236


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 10 January 2023 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 33-126450

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



MT Tonsi
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	: Air Circuit-Breaker
Trade name(s)	: CHINT
Type(s)/model(s)	: NXA32H, NXA32N and NXA32S
Number of poles	: 3P or 4P
Rated operational voltage (Ue)	: 380 / 400 / 415 Vac, 440 / 525 / 690 Vac
Rated insulation voltage (Ui)	: 1000 V for main circuit 415 V for control circuit 415 V for auxiliary circuit
Rated impulse withstand voltage (Uimp)	: 12 kV for main circuit 6 kV for control circuit 6 kV for auxiliary circuit
Rated frequency	: 50 / 60 Hz
Rated current (In)	: 3200 A, 2500 A, 2000 A, 1600 A
Conventional thermal current (Ith)	: Equal to In
Current rating for four-pole circuit-breakers	: 50% In, 100% In adjustable
Individual pole short-circuit (Itr)	: 12 In at 380 / 400 / 415 / 440 / 525 Vac
Suitable for isolation	: Suitable
Selectivity category	: B
Safety distance (screen-circuit breaker)	: Left / Right: 0 mm Up / Down: 0 mm Front / Back: 0 mm
Reference temperature	: Independent
Method of mounting	: Fixed or Withdrawable
EMC environment	: A
Tightening torque for terminals	: 50 Nm for M12
Line/load terminal	: Immaterial
Connection	: Copper busbar minimum cross-sectional area of conductor (mm ²): (100 x 5) mm ² x 2 maximum cross-sectional area of conductor (mm ²): (100 x 10) mm ² x 4
Electronic trip unit type(s)	: NKD6 series: NKD6-M, NKD6-A, NKD6-P and NKD6-H
Inverse time delay release	: Ir (inverse time delay tripping setting): For trip units: NKD6-P, NKD6-H (0,4 - 1) x In, in steps of 1 A For trip units: NKD6-M and NKD6-A (0,4 / 0,5 / 0,6 / 0,7 / 0,8 / 0,9 / 1) x In
Time setting of the inverse time delay release	: tr (inverse time delay tripping setting): 1 s / 2 s / 4 s / 8 s / 12 s / 16 s / 20 s / 24 s, with tolerance of $\pm 15\%$ (at 6 Ir) 2 Ir tripping time declared by the manufacturer: when tr = 1 s: 7,65 s - 10,35 s when tr = 24 s: 183,6 s - 248,4 s
Short time delay release	: Isd (short time delay tripping setting): For trip units: NKD6-P, NKD6-H (2 - 10) x Ir, in steps of 1 A For trip units: NKD6-M and NKD6-A (2 / 3 / 4 / 5 / 6 / 8 / 10) x Ir

Time setting of the short time delay release	: tsd (short time delay tripping setting): I ² t off: 0,1 s / 0,2 s / 0,3 s / 0,4 s 0,1 s, with tolerance of 60 ms - 140 ms 0,2 s, with tolerance of 160 ms - 240 ms 0,3 s, with tolerance of 255 ms - 345 ms 0,4 s, with tolerance of 340 ms - 460 ms non-tripping duration stated by the manufacturer: 0,1 s: 50 ms 0,2 s: 140 ms 0,3 s: 250 ms 0,4 s: 330 ms
Instantaneous release	: li (instantaneous tripping setting): For trip units: NKD6-P, NKD6-H (2 - 15) x I _n , in steps of 1 A For trip units: NKD6-M and NKD6-A (2 / 4 / 6 / 8 / 10 / 12 / 15) x I _n
Making current release (MCR)	: 26 kA
Ground fault release	: lg (ground fault release tripping setting): For trip units: NKD6-P and NKD6-H 500 A - 1200 A, in steps of 1 A For trip units: NKD6-M and NKD6-A 500 A / 640 A / 800 A / 960 A / 1040 A / 1120 A / 1200 A
Time setting of the ground fault release	: tg (ground fault release tripping setting): I ² t off: 0,1 s / 0,2 s / 0,3 s / 0,4 s 0,1 s, with tolerance of 60 ms - 140 ms 0,2 s, with tolerance of 160 ms - 240 ms 0,3 s, with tolerance of 255 ms - 345 ms 0,4 s, with tolerance of 340 ms - 460 ms
Shunt release	: 220 / 230 / 240 Vac, 380 / 400 / 415 Vac; 50 / 60 Hz 110 Vdc, 220 Vdc
Under-voltage release	: 220 / 230 / 240 Vac, 380 / 400 / 415 Vac; 50 / 60 Hz
Closing coil	: 220 / 230 / 240 Vac, 380 / 400 / 415 Vac; 50 / 60 Hz 110 Vdc, 220 Vdc
Stored energy motor	: 220 / 230 / 240 Vac, 380 / 400 / 415 Vac; 50 / 60 Hz 110 Vdc, 220 Vdc
Power modules for trip unit	: 220 / 230 / 240 Vac, 380 / 400 / 415 Vac; 50 / 60 Hz 110 Vdc, 220 Vdc
Auxiliary circuits	: 6NO6NC, 4NO4NC AC-15: 1,3 A at 240 Vac, 0,75 A at 415 Vac; 50 / 60 Hz DC-13: 0,55 A at 110 Vdc, 0,27 A at 220 Vdc Ui: 415 V, U _{imp} : 6 kV, I _{th} : 6 A rated conditional short-circuit current: 1 kA SCPD: NT00-6, 6 A

Product data – type NXA32H

Rated service short-circuit breaking capacity (I _{cs})	: 85 kA at 380 / 400 / 415 Vac 70 kA at 440 / 525 / 690 Vac
Rated ultimate short-circuit breaking capacity (I _{cu})	: 100 kA at 380 / 400 / 415 Vac 70 kA at 440 / 525 / 690 Vac
Rated short-time withstand current (I _{cw})	: 85 kA / 1 s at 380 / 400 / 415 Vac 50 kA / 3 s at 380 / 400 / 415 Vac 70 kA / 1 s at 440 / 525 / 690 Vac

Product data – type NXA32N

Rated service short-circuit breaking capacity (I _{cs})	: 80 kA at 380 / 400 / 415 Vac 65 kA at 440 / 525 / 690 Vac
--	--

Rated ultimate short-circuit breaking capacity (Icu) : 80 kA at 380 / 400 / 415 Vac
65 kA at 440 / 525 / 690 Vac
Rated short-time withstand current (Icw) : 65 kA / 1 s at 380 / 400 / 415 Vac
37 kA / 3 s at 380 / 400 / 415 Vac
65 kA / 1 s at 440 / 525 / 690 Vac

Product data – type NXA32S

Rated service short-circuit breaking capacity (Ics) : 80 kA at 380 / 400 / 415 Vac
70 kA at 440 / 525 / 690 Vac
Rated ultimate short-circuit breaking capacity (Icu) : 80 kA at 380 / 400 / 415 Vac
70 kA at 440 / 525 / 690 Vac
Rated short-time withstand current (Icw) : 80 kA / 1 s at 380 / 400 / 415 Vac
50 kA / 3 s at 380 / 400 / 415 Vac
70 kA / 1 s at 440 / 525 / 690 Vac

TESTS**Test requirements**

EN 60947-2:2017
EN 60947-2:2017/A1:2020
IEC 60947-2:2016
IEC 60947-2:2016/A1:2019
IEC 60947-5-1:2016
EN 60947-5-1:2017

Test result

The test results are laid down in DEKRA test file 332629900.

Additional information

NXA32N / x, NXA32S / x, NXA32H / x
x- represents number of poles, 4 for 4P, blank for 3P

The referred test reports are 3326299.50, 3312363.51, CQC CB test reports no. 00901-CB2015CQC-067841 issued on 2015-12-28 and no. 00901-CB2015CQC-067841-M1 issued on 2017-06-22 with CQC CB test certificate no. CN36361-A1/M1 issued on 2017-07-14.

This certificate replaces certificate No. 33-106884 which we hereby declare invalid.

Conclusion

The examination proved that all requirements were met.

Factory location

Zhejiang Chint Electrics Co., Ltd.
No. 1318, Binhai No. 2 Avenue, Economic and Technical Development Zone,
325025 Wenzhou Zhejiang, China