CERTIFICATE

Issued to: Applicant: Zhejiang Chint Electrics Co., Ltd. No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang, China

Licensee: Zhejiang Chint Electrics Co., Ltd. No. 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, 325603 Zhejiang, China

Product	:	Air Circuit-Breaker
Trade name(s)	:	CHINT
Type(s)/model(s)	:	NXA40N

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-2:2017 and EN 60947-5-1/2017
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2032236

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 21 December 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 33-106780

DEKRA Certification B.V.

B.T.M. Holtus Managing Director

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH ACCREDITATION COUNCIL

H.R.M. Barends Certification Manager





DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Company registration 09085396

DEKRA



page 1 of 3

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data	
Product	: Air Circuit-Breaker
Trade name(s)	: CHINT
Type(s)/model(s)	: NXA40N
Number of poles	: 3P or 4P (N pole with protection)
Protected poles	: 3 or 4
Rated operational voltage (Ue)	: 380 / 400 / 415 Vac, 440 / 525 / 690 Vac
Rated insulation voltage (Ui)	: 1000 V for main circuit
	415 V for control circuit
Deted impulse withstand values	415 V for auxiliary circuit : 12 kV for main circuit
Rated impulse withstand voltage (Uimp)	6 kV for control circuit
(Omp)	6 kV for auxiliary circuit
Rated frequency	: 50 / 60 Hz
Rated current (In)	: 4000 A, 3600 A, 3200 A
Conventional thermal current (Ith)	: Equal to In
Current rating for four-pole circuit-	50% In, 100% In adjustable
breakers	· · · · · · · · · · · · · · · · · · ·
Rated service short-circuit breaking	: 80 kA at 380 / 400 / 415 Vac
capacity (Ics)	65 kA at 440 / 525 / 690 Vac
Rated ultimate short-circuit breaking	: 80 kA at 380 / 400 / 415 Vac
capacity (Icu)	65 kA at 440 / 525 / 690 Vac
Rated short-time withstand current	: 65 kA / 1 s at 380 / 400 / 415 Vac
(Icw)	37 kA / 3 s at 380 / 400 / 415 Vac
	65 kA / 1 s at 440 / 525 / 690 Vac
Individual pole short-circuit (IIT)	: 12 In at 380 / 400 / 415 / 440 / 525 Vac
Suitable for isolation	: Suitable : B
Selectivity category Safety distance (screen-circuit	: D : Left / Right: 0 mm
breaker)	Up / Down: 0 mm
breaker)	Front / Back: 0 mm
Reference temperature	: Independent
Method of mounting	: Fixed or Withdrawable
EMC environment	: A
Tightening torque for terminals	: 50 Nm for M12
Line/load terminal	: Immaterial
Connection	: Copper busbar
	For In = 3200 A,
	cross-sectional area of conductor (mm ²): (100 x 10) mm ² x 4
	For In = 3600 A - 4000 A,
	cross-sectional area of conductor (mm ²): (100 x 10) mm ² x 5
Electronic trip unit type(s)	: NKD6 series:
	NKD6-M, NKD6-A, NKD6-P and NKD6-H NST1-D series:
	NST1-D series. NST1-DM, NST1-DA, NST1-DP and NST1-DH
Inverse time delay release	: Ir (inverse time delay tripping setting):
inverse time delay release	For trip units: NKD6-P, NKD6-H
	$(0,4 - 1) \times In$, in steps of 1 A
	For trip units: NST1-DM, NST1-DA, NST1-DP and NST1-DH
	(0,4 - 1) x In, in steps of 2 A
	For trip units: NKD6-M and NKD6-A
	(0,4 / 0,5 / 0,6 / 0,7 / 0,8 / 0,9 / 1) x ln

ANNEX TO KEMA-KEUR CERTIFICATE 33-106780



page 2 of 3

Time setting of the inverse time delay release	 tr (inverse time delay tripping setting): 1 s / 2 s / 4 s / 8 s / 12 s / 16 s / 20 s / 24 s, with tolerance of ± 15% (at 6 lr) 2 Ir tripping time declared by the manufacturer: when tr = 1 s: 7,65 s - 10,35 s
Short time delay release	when tr = 24 s: 183,6 s - 248,4 s : Isd (short time delay tripping setting): For trip units: NKD6-P, NKD6-H (2 - 10) x Ir, in steps of 1 A For trip units: NST1-DM, NST1-DA, NST1-DP and NST1-DH (2 - 10) x Ir, in steps of 2 A for Ii < 10 kA, in steps of 0,02 kA for Ii \ge 10 kA For trip units: NKD6-M and NKD6-A (0.145 (0.145))
Time setting of the short time delay release	$(2/3/4/5/6/8/10) \times Ir$: tsd (short time delay tripping setting): I ² t off: 0,1 s / 0,2 s / 0,3 s / 0,4 s 0,1 s, with tolerance of 60 ms - 140 ms 0,2 s, with tolerance of 160 ms - 240 ms 0,3 s, with tolerance of 255 ms - 345 ms 0,4 s, with tolerance of 340 ms - 460 ms non-tripping duration stated by the manufacturer: 0,1 s: 50 ms 0,2 s: 140 ms 0,3 s: 250 ms 0,4 s: 330 ms
Instantaneous release	 Ii (instantaneous tripping setting): Max 50 kA For trip units: NKD6-P, NKD6-H (2 - 15) x In, in steps of 1 A For trip units: NST1-DM, NST1-DA, NST1-DP and NST1-DH (2 - 15) x In, in steps of 2 A for Ii < 10 kA, in steps of 0,02 kA for Ii ≥ 10 kA For trip units: NKD6-M and NKD6-A (2 / 4 / 6 / 8 / 10 / 12 / 15) x In
Making current release (MCR) Ground fault release	 26 kA Ig (ground fault release tripping setting): For trip units: NKD6-P and NKD6-H 500 A - 1200 A, in steps of 1 A For trip units: NST1-DM, NST1-DA, NST1-DP and NST1-DH 500 A - 1200 A, in steps of 2 A For trip units: NKD6-M and NKD6-A 500 A / 640 A / 800 A / 960 A / 1040 A / 1120 A / 1200 A
Time setting of the ground fault release	: tg (ground fault release tripping setting): $l^{2}t$ off: 0,1 s / 0,2 s / 0,3 s / 0,4 s 0,1 s, with tolerance of 60 ms - 140 ms 0,2 s, with tolerance of 160 ms - 240 ms 0,3 s, with tolerance of 255 ms - 345 ms 0,4 s, with tolerance of 340 ms - 460 ms
Shunt release	: 220 / 230 / 240 Vac, 380 / 400 / 415 Vac;
Under-voltage release Closing coil	110 Vdc, 220 Vdc : 220 / 230 / 240 Vac, 380 / 400 / 415 Vac : 220 / 230 / 240 Vac, 380 / 400 / 415 Vac; 110 Vdc, 220 Vdc
Stored energy motor	: 220 / 230 / 240 Vac, 380 / 400 / 415 Vac; 110 Vdc, 220 Vdc



Auxiliary circuits

6NO6NC, 4NO4NC
 AC-15: 1,3 A at 240 Vac, 0,75 A at 415 Vac; 50 / 60 Hz
 DC-13: 0,55 A at 110 Vdc, 0,27 A at 220 Vdc
 Ui: 415 V, Uimp: 6 kV, Ith: 6 A
 rated conditional short-circuit current: 1 kA
 SCPD: NT00-6, 6 A

TESTS

Test requirements

EN 60947-2:2017 EN 60947-5-1:2017

Test result

The test results are laid down in DEKRA test file 331336900.

Additional information

Nomenclature breakdown NXA40N / x x- represents number of poles, 4 for 4P, blank for 3P

The referred test reports are 3313369.50, 3312363.51 and CQC CB test report no. 00901-CB2015CQC-067840 issued on 2015-12-29 with CQC CB test certificate no. CN36359 issued on 2016-01-26.

The product also complies with IEC 60947-2:2016, IEC 60947-5-1:2016.

Conclusion

The examination proved that all requirements were met.

Factory location

Zhejiang Chint Electrics Co., Ltd. No. 1318, Binhai No. 2 Avenue, Economic and Technical Development Zone, 325025 Wenzhou, Zhejiang, China