



Product Compliance Certificate

Certificate Number: 5014091S230010-01A

Certification is based on the type testing according to below named standards and production is monitored by an Initial and Annual Follow up Inspection Service.

Notice to Authorities:

This certificate indicates that a third party Accredited Body has tested and verified that the products listed comply with the relevant harmonized standards to directives listed on this certificate. The manufacturer may indicate compliance to said directive by signing a Declaration of Conformity to products identical to the tested samples.

In addition, annual factory inspection has been performed for further verification of compliance. Intertek requests all whom may be concerned to allow products entry into the European market without delay or prejudice. The applicant may rightfully use this certificate to mark their products with the ETL^{EU} mark identified above.

Intertek is a leading international provider of quality and safety services to a wide range of global and local industries. Intertek's laboratories are included in IECCE CB scheme as operational CBTL and hold several local accreditations.

For further information:
Email: ETL.EU@intertek.com
Website: www.intertek.com/ETLeu

Or Certification Body:
Intertek Testing Services Ltd.
Shanghai
West Area, 2nd Floor, No. 707,
Zhangyang Road, China
(Shanghai) Pilot Free Trade Zone,
Shanghai, P. R. China

Applicant

Zhejiang Chint Electrics Co., Ltd.
No 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang
P. R. China

Manufacturing Site

Zhejiang Chint Electrics Co., Ltd.
No 1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang
P. R. China

Product Name

Moulded Case Circuit-Breakers (MCCBs)

Trademark

CHINT

Model Number(s)

NXB-63G *

Description

Details see attachment

Test Report No

2309A0766SHA-001

Standards/Directives

EN 60947-2: 2017+A1:2020; IEC 60947-2: 2016+A1:2019
SANS 60947-2: 2020; SANS 556-1: 2018; VC8036: 2017

Issued Date

November 27, 2023

Validity

November 26, 2028

Maximum 5 years or the validity limitation of the standards/directives used, whichever is sooner.

Safety related parts of the user instructions shall be written in a language acceptable to the country where the product is to be used.

This certificate, which includes production control, is considered to constitute sufficient support for an EC Declaration of Conformity and CE marking of the product according to the Low Voltage Directive 2014/35/EU. Other EU directives may apply.

Gary Hu



Attachment to Certificate Number: 5014091S230010-01A

Model Number(s):

NXB-63G *

a) b)

a) Product Design

b) * means rated current: In: 1A, In: 2A, In: 4A ... In: 63A

Description:

$U_e = AC220V/230V/240V(1P), AC380V/400V/415V(2P, 3P, 4P)$

$I_n = 1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A$

$I_{cu} = I_{cs} = 6kA, Cat. A, I_i = 14,2I_n, 10I_n$

ref. temperature: +40°C