



Ref. Certif. No.

SE-95084

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Circuit-breakers for overcurrent protection for household and similar installations (CBOs)
Name and address of the applicant	Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixia, Yueqing, Zhejiang Province, P.R. China 325603
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	U _n = 220V~, 230V~, 240V~ (1P, 1P+N) U _n = 380V~, 400V~, 415V~ (2P, 3P, 3P+N, 4P) I _n = 1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	NXB-63H
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 60898-1:2015
As shown in the Test Report Ref. No. which forms part of this Certificate	190300991SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 13 August 2019



Signature:

Leif Mattsson