



# CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE230303008079-A1

**Product** Miniature Circuit-breakers

**Applicant** Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang  
Town, Yueqing City, Zhejiang Province, P.R.China

**Type/Model** NXB-80,NXB-80E

**Technical data** See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2022CQC0303-013480-A1, the submitted sample(s) of the above item complies with:

**EN 60898-1:2019**

and fulfills testing requirements of the European Directive:

**2014/35/EU**

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

**Valid from: May.30,2023**

**Valid until: Mar.15,2026**

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE





# CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE230303008079-A1

NXB-80,NXB-80E

Uimp: 4kV;

Ui: 500V;

Ue: AC220V/230V/240V(1P,1P+N,2P),AC380V/400V/415V (2P,3P,3P+N,4P);

In: 70A, 80A;

Instantaneous tripping current: B,C,D;

Icn1:6000A,10000A(Only 2P,AC220V/230V/240V);

Icn:6000A,10000A(Only 2P,AC220V/230V/240V);

Ics:6000A,7500A(Only 2P,AC220V/230V/240V);

Poles: 1P,1P+N(1 protected pole with a switched neutral pole),2P,3P,3P+N(3 protected pole with a switched neutral pole),4P;

Applicable for isolation



CHINA QUALITY CERTIFICATION CENTRE

