



# CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE230305008550

**Product** Contactor For Capacitor Switching

**Applicant** Zhejiang CHINT Electric Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang  
Town, Yueqing City, Zhejiang Province, P.R.China

**Type/Model** NXCC-25\*\*;

**Technical data** See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. (2023)FQIIDQCE-0329, the submitted sample(s) of the above item complies with:

**EN IEC 60947-4-1:2019**

and fulfills testing requirements of the European Directive:

**2014/35/EU**

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

**Valid from: Oct.13,2023**

**Valid until: Oct.12,2026**

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



# CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE230305008550

NXCC-25\*\*

(\*\*=Type and quantity of auxiliary contacts);

Ui:690V;Uimp:6kV;Ue:AC220V/230V,

AC380V/400V,AC660V/690V;

Ith:25A;AC-6b:Ue/Ie: AC220V/230V/19A,

AC380V/400V/19A,AC660V/690V/19A;

Qe:AC220V/230V/7.2kvar,

AC380V/400V/12.5kvar,

AC660V/690V/21.7kvar;

Us:AC24V,AC36V,AC42V,AC48V,AC110V,

AC120V,AC127V,AC220V,AC230V,AC240V,AC277V,AC380V,AC400V,AC415V, AC440V,

AC460V,AC480V,AC525V,AC600V,AC660V/50Hz,50/60Hz,60Hz;3P;

IP20(Only applicable to the front side) ;

Attached auxiliary contacts: 2NO1NC,

1NO2NC;Ui:690V;Uimp:6kV;Ith:10A;

AC-15:Ue/Ie:AC220V/230V/2.7A,

AC380V/400V/1.5A;

DC-13:Ue/Ie:DC220V/0.3A



CHINA QUALITY CERTIFICATION CENTRE