




Valued Quality. Delivered.

Intertek Testing Services Shanghai
Building No.86, 1198 Qinzhou Road (North),
Caohejing Development Zone,
Shanghai 200233, China
Tel:86 21 6127 8200 Fax:86 21 6495 6263

Test Verification of Conformity

On the basis of the referenced test report(s), sample(s) of the below product have been found to comply with the harmonized standards and Directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product.

Once all product relevant  mark directives are verified in compliance, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to product identical to the test sample(s) if the product complies with all relevant CE mark Directives requirements.

Applicant Name & Address : Zhejiang Chint Electric Co., Ltd.
No.1, Chint Road, Chint Industrial Zone, North Baixiang,
Yueqing, Zhejiang Province, P.R.China, 325603

Manufacturing site Name & Address : Same as applicant

Product(s) Tested : Low-voltage switchgear and controlgear:
Control circuit devices and switching elements
Electromechanical control circuit devices

Ratings and principal characteristics : See annex page

Model(s) : NXRC-40, NXRC-31, NXRC-22, NXRC-13, NXRC-04

Brand name : CHINT

Relevant Standard(s) / Specification(s) / Directive(s) : EN 60947-5-1:2016
Low Voltage Directive 2014/35/EU

Verification Issuing Office Name & Address : Intertek Testing Services Shanghai
Building No.86, 1198 Qinzhou Road (North), Shanghai 200233,
China


Verification Number : 160901793SHA-V1

Report Number(s) : 160901793SHA-001

NOTE 1: This verification is part of the full test report(s) and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Oliver Wei
Manager
November 02, 2016



Valued Quality. Delivered.

Intertek Testing Services Shanghai
Building No.86, 1198 Qinzhou Road (North),
Caohejing Development Zone,
Shanghai 200233, China
Tel:86 21 6127 8200 Fax:86 21 6495 6263

Annex to Test Verification of Conformity

This is an Annex to Test Verification of Conformity with 160901793SHA-V1. The issuing office is Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China

Type:	NXRC-40, NXRC-31, NXRC-22, NXRC-13, NXRC-04		
Rating:	Ui= 690V, Uimp= 6kV, IP20		
Ue (V):	AC 380V	AC 400V	DC 220V
Ie (A):	AC-15: 1,5A	AC-15: 1,5A	DC-13: 0,3A
Ith (A):	10A		
Control circuit:	AC: Us= 24, 36, 48, 110, 127, 220, 380, 415V~, 50Hz		
	DC: Us= 24, 48, 110, 220V		
Rated conditional short-circuit current	1000A		

NOTE 1: This verification is part of the full test report(s) and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Oliver Wei
Manager
November 02, 2016